



Facilities Management
Design & Construction

Deviation Request Number: _____

DEVIATION REQUEST FORM

This form shall be used by Design Professional to request a deviation from the Design Standards & Procedures and must be completed prior to bid document phase. Please complete and return via email to the UI Project Manager in .pdf format.

Date: _____ Project Phase: _____
(SD, DD, CD)

UI Project Name: _____

UI Project Number: _____ Owner's Design Project Manager: _____

Design Professional: _____

Design Professional Representative: _____
(first and last name)

Email Address: _____ Phone: (_____)

Design Standards Edition: July 30, 2020 Section Number: IV 5.3.1.2 Page Number: 363

Description of Deviation: (attach additional page(s) as needed)
Temperature Color Temperature shall be 4000K in all Operating Rooms and Cath Labs.

Justification for Deviation Request: (attach additional page(s) as needed)
UIHC preferred color temperature in these locations is 4000K

Attachment List: _____ Total number of pages attached: _____

Reviewed / Approved By:

(Responses NA – not applicable, R&A – reviewed & approved, RAN – reviewed as noted, R&R – revise & resubmit, NR – not recommended):

R&A

<p>1) UIHC Capital Management ^{10/13/2020} (Department Name) _____ _____ Response DocuSigned by: <u>Luke Levden</u> Luke Levden (Printed Name & Initial)</p>	<p>2) UIHC Engineering Services ^{10/13/2020} (Department Name) _____ _____ Response DocuSigned by: <u>Bob Miller</u> Bob Miller (Printed Name & Initial)</p>	<p>3) _____ (Department Name) _____ _____ Response (Printed Name & Initial)</p>	<p>4) _____ (Department Name) _____ _____ Response (Printed Name & Initial)</p>
<p>5) _____ (Department Name) _____ _____ Response (Printed Name & Initial)</p>	<p>6) _____ (Department Name) _____ _____ Response (Printed Name & Initial)</p>	<p>7) _____ (Department Name) _____ _____ Response (Printed Name & Initial)</p>	<p>8) _____ (Department Name) _____ _____ Response (Printed Name & Initial)</p>

(B&LS, UIU (Ben Fish), Public Safety and FIMS required for all main campus deviations. Capital Management, Engineering Services required for all UIHC deviations. Include all other departments/stakeholders impacted: P&T, ITS, Campus Planning, Safety & Security, HCIS, etc.)

Chet Wieland ^{10/13/2020}