



Facilities  
Management  
Design & Construction

**THE UNIVERSITY OF IOWA  
DESIGN STANDARDS & PROCEDURES**

**07-30-2021 EDITION**

**PREFERMENT #03  
UIHC HVAC Pump Flex Connectors**

EFFECTIVE DATE: January 18, 2022

---

The information contained in this Preferment modifies, supplements, or replaces information contained in The University of Iowa Design Standards & Procedures.

---

APPLICABLE SECTION: **Section III – General Design Standards and Outline Specifications and Details**

ATTACHMENT(S): **None**

---



**APPLICABLE TO SECTION III – General Design Standards and Outline Specifications and Details:**

ITEM #1      23) Heating, Ventilating, and Air Conditioning (HVAC)

4.18.5 HVAC Pumps:

Insert new article 4.18.5.1.2.1: For UIHC: HVAC pumps shall be supplied with Stainless Steel flex connectors; rubber flex connectors are not allowed.

**END OF PREFERMENT**