



Facilities
Management
Design & Construction

**THE UNIVERSITY OF IOWA
DESIGN STANDARDS & PROCEDURES**

07-30-2021 EDITION

**PREFERMENT #04
UIHC Heating Water Piping**

EFFECTIVE DATE: January 18, 2022

The information contained in this Preferment modifies, supplements, or replaces information contained in The University of Iowa Design Standards & Procedures.

APPLICABLE SECTION: **Section III – General Design Standards and Outline Specifications and Details**

ATTACHMENT(S): **None**



APPLICABLE TO SECTION III – General Design Standards and Outline Specifications and Details:

ITEM #1 23) Heating, Ventilating, and Air Conditioning (HVAC)

4.18.4. HVAC Piping Systems:

Insert new article 4.18.4.3.5.2: All heating water piping is to be welded or copper piping. Lock and groove VITAULIC style pipe is not approved for use in UIHC.

END OF PREFERMENT