

UNIVERSITY OF IOWA OAKDALE CAMPUS UTILITY PLANT PIPING STANDARD SPECIFICATIONS

TABLE OF CONTENTS

PIPE SPECIFICATION	SYSTEM	DESIGN CONDITIONS		OPERATING CONDITIONS		PAGE	REV	DATE
		PRESSURE (PSIG)	TEMPERATURE (°F)	PRESSURE (PSIG)	TEMPERATURE (°F)			
UI-LPS	LOW PRESSURE STEAM	50	340	20	260	2	0	2/22/2021
UI-HPS	HIGH PRESSURE STEAM	175	500	150	365	3	0	2/22/2021
UI-LP-CON	LOW PRESSURE CONDENSATE	50	340	20	260	4	0	2/22/2021
UI-HP-CON	HIGH PRESSURE CONDENSATE	175	500	150	365	5	4	2/22/2021
UI-HW	HOT WATER SUPPLY	245	250	130	215	6	0	2/22/2021
UI-HW	HOT WATER RETURN	245	250	130	150	6	0	2/22/2021
UI-VENT	RELIEF DEVICE VENT PIPING	250	500	NOTE 1		7	0	2/22/2021
UI-ED	EQUIPMENT DRAIN PIPING	250	500	NOTE 1		8	0	2/22/2021
UI-FW	BOILER FEEDWATER	250	300	200	230	9	0	2/22/2021
UI-GFS	NATURAL GAS	150	150	28	55	10	3	2/22/2021
UI-AIR	COMPRESSED AIR	150	150	80-100	75	11	3	2/22/2021
UI-MUS-PWS	MAKE-UP WATER	150	150	100	55	12	6	2/22/2021
UI-MUS-PWS	POTABLE WATER	150	150	60	55	12	6	2/22/2021
UI-SEW	SANITARY SEWER	15	140	0	75	13	2	2/22/2021
UI-BOS-BDS	BOILER BLOWOFF	250	400	150	366	14	0	2/22/2021
UI-BOS-BDS	BOILER BLOWDOWN	250	400	150	366	14	0	2/22/2021
UI-CHW	CHILLED WATER	150	100	50-120	SUPPLY: 42 RETURN: 54-60	15	0	2/22/2021
UI-CS (DI)	CONDENSER WATER (DI)	150	150	50-75	SUPPLY: 85 RETURN: 95-102	16	0	2/22/2021
UI-CS (CS)	CONDENSER WATER (CS)	150	150	50-75	SUPPLY: 85 RETURN: 95-102	17	0	2/22/2021
UI-CS (SS)	CONDENSER WATER (SS)	150	150	50-75	SUPPLY: 85 RETURN: 95-102	18	0	2/22/2021
UI-CS-DRAIN	CONDENSER WATER DRAINS	150	120	50-75	SUPPLY: 85 RETURN: 95-102	19	0	2/22/2021
UI-PCW (CS)	PROCESS COLD WATER - CS	135	200	60-80	55	20	2	2/22/2021
UI-PCW (SS)	PROCESS COLD WATER - SS	150	100	60-80	55	21	1	2/22/2021
UI-PCW (DI)	PROCESS COLD WATER - DI	150	100	60-80	55	22	0	2/22/2021
UI-CSS	SAMPLE WATER	150	100	50-75	95-102	23	0	2/22/2021
UI-CHEM (SS)	CHEMICAL FEED	150	140	NOTE 1		24	2	2/22/2021
UI-CHEM (PVC)	CHEMICAL FEED	150	140	NOTE 1		25	0	2/22/2021
UI-CHEM (CPVC)	CHEMICAL TREATMENT SERVICE	150	100	50-75	75	26	0	2/22/2021
UI-CHEM (PVDF)	CHEMICAL TREATMENT SERVICE - ACID	150	100	50-75	75	27	0	2/22/2021
UI-DCW	DOMESTIC WATER SYSTEM	135	200	60	COLD: 50 HOT: 150	28	0	2/22/2021
UI-LOL	LUBE OIL	230	100	10	75-95	29	0	2/22/2021
UI-REF	REFRIGERANT	300	250	NOTE 1		30	0	2/22/2021
UI-RV	REFRIGERANT VENT PIPING	285	150	NOTE 1		31	0	2/22/2021
	BRANCH TABLE					32	1	2/22/2021

NOTES

- 1) OPERATING CONDITIONS DETERMINED ON A SYSTEM BY SYSTEM BASIS
- 2) ALL SYSTEMS ARE ABOVE GROUND UNLESS OTHERWISE STATED

LOW PRESSURE STEAM (TO 50 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-LPS	PIPE SIZE (NPS)	LOW PRESSURE STEAM		50 PSIG AT 340 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 24"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	XS		STD	
	CONSTRUCTION	A106 GRADE B - SEAMLESS		A106 GRADE B - SEAMLESS	
FITTINGS:	WALL THICKNESS	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
	MATERIAL	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
PIPING JOINTS:	TYPE	FORGED CARBON STEEL - ASTM A105		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
	OTHER	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
UNIONS:	CONSTRUCTION	WHERE FLANGE OR THREAD REQUIRED		WHERE FLANGE REQUIRED	
	WALL THICKNESS	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN		NOT PERMITTED	
	MATERIAL	SAME AS ADJOINING PIPE		--	
FLANGES:	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105		--	
	WALL THICKNESS	CLASS 150 - WELD NECK - ASME B16.5		--	
	MATERIAL	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
FLANGE BOLTS:	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105		FORGED CARBON STEEL - ASTM A105	
FLANGE NUTS:	CONSTRUCTION	ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7			
WASHER:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H			
GASKETS:	CONSTRUCTION	F436			
	MATERIAL	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES			
THERMOWELLS:	CONSTRUCTION	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER			
	MATERIAL	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS			
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:	DATE REVISED:	
CARBON STEEL	ASTM B36.10M	ASME B31.1	0	2/22/2021	
VENT PIPING FINISH:	SPECIFICATION MATERIAL:	2-COAT SYSTEM WITH SOLVENT-BASED INORGANIC ZINC PRIMER, AND INORGANIC SILICATE POLYMER TOP COAT - COLOR TO MATCH RED OF EXISTING RELIEF DEVICE PIPING			
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-LPS	CARBON STEEL	150 PSIG	ASME B31.1	ASME B16.34	
	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 24"	
GATE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD (1" THRU 2")		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105, TRIM 13% CR OUTSIDE SCREW & YOKE, BOLTED GLAND, SOLID WEDGE, HARD FACED SEATS, CLASS 800 PACKING: GRAPHITE		BODY/BONNET: A216 GR. WCB SEAT RING: HARDFACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SS WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12111 BONNEY FORGE FIG. H11SW		POWELL FIGURE 1503 CRANE FIGURE 47 BONNEY FORGE 1-11 RF	
BUTTERFLY VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/BONNET: A216 GR. WCB SEAT RING: METAL SEAT DISC: A351 CF8M SHAFT: 17-4 PH PACKING: PTFE GLAND: 304 SS	
	VALVE SELECTION	--		POWELL FIGURE 1572 DEZURIK STYLE BHP FLOWSEAL TYPE 1LA	
CHECK VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY/CAP: A105 (BOLTED) SWING CHECK SEAT RING: STELLITE 6 FACED 410 SS DISC: 13% CR GASKET: SPIRAL WOUND		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SW701 BONNEY FORGE FIG. H61SW		POWELL FIGURE 1561 CRANE FIGURE 147 BONNEY FORGE 1-61 RF	
BALL VALVE	CONNECTION AND RATING	CLASS 900 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS (UP TO 6")	
	CONSTRUCTION	BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CHROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER		BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CHROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER (GEAR OPERATOR OVER 4")	
	VALVE SELECTION	VELAN TYPE R, METAL SEATED, CLASS 900		VELAN TYPE R	
GLOBE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105 (BOLTED) (BODY HARDFACED) DISC: 420SST TRIM: 13% Cr STEM: A183 F6A PACKING: GRAPHITE GASKET: SPIRAL WOUND SST WITH GRAPHITE		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SW12141 BONNEY FORGE FIG. H31SW		POWELL FIGURE 1531 CRANE FIGURE 143 BONNEY FORGE 1-31 RF	
REVISION HISTORY					
NUMBER	DESCRIPTION		DATE		
0	INITIAL ISSUE		2/22/2021		

HIGH PRESSURE STEAM (TO 175 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-HPS	PIPE SIZE (NPS)	HIGH PRESSURE STEAM		175 PSIG AT 500 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 24"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	XS		STD	
	CONSTRUCTION	A106 GRADE B - SEAMLESS		A106 GRADE B - SEAMLESS	
FITTINGS:	WALL THICKNESS	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
	MATERIAL	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
PIPING JOINTS:	TYPE	FORGED CARBON STEEL - ASTM A105		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
	OTHER	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
UNIONS:	CONSTRUCTION	WHERE FLANGE OR THREAD REQUIRED		WHERE FLANGE REQUIRED	
	WALL THICKNESS	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN		NOT PERMITTED	
	MATERIAL	SAME AS ADJOINING PIPE		--	
FLANGES:	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105		--	
	WALL THICKNESS	CLASS 300 - WELD NECK - ASME B16.5		--	
	MATERIAL	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
FLANGE BOLTS:	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105		FORGED CARBON STEEL - ASTM A105	
FLANGE NUTS:	CONSTRUCTION	ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7			
WASHER:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H			
GASKETS:	CONSTRUCTION	F436			
	MATERIAL	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES			
THERMOWELLS:	CONSTRUCTION	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER			
	MATERIAL	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS			
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1		0	2/22/2021
VENT PIPING FINISH:	SPECIFICATION MATERIAL:	2-COAT SYSTEM WITH SOLVENT-BASED INORGANIC ZINC PRIMER, AND INORGANIC SILICATE POLYMER TOP COAT COLOR TO MATCH RED OF EXISTING RELIEF DEVICE PIPING			
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-HPS	CARBON STEEL	300 PSIG	ASME B31.1	ASME B16.34	
	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 24"	
GATE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		BUTTWELD ENDS	
	CONSTRUCTION	BODY/BONNET: A105, TRIM 13% CR OUTSIDE SCREW & YOKE, BOLTED GLAND, SOLID WEDGE, HARD FACED SEATS, CLASS 800 PACKING: GRAPHITE		BODY/BONNET: A105 OR A216 GR. WCB SEAT RING: HARDFACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: SPIRAL WOUND SS WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12111 BONNEY FORGE FIG. H11SW		POWELL FIGURE 3003 CRANE FIGURE 33-1/2 BONNEY FORGE 3-11 BW	
BUTTERFLY VALVE	CONNECTION AND RATING	--		BUTTWELD ENDS	
	CONSTRUCTION	--		BODY: A216 GR. WCB CAP: A 516 GR 60 OR A 696 GR B CLOSE STOP: A 516 GR 60 DRIVE SHAFT: A 276 GR 431 DISC: A351 CF8M BEARING: A 439 TPD2 SEAL/SEAT GASKET: GRAPHITE BEARING SEAL: GRAPHITE GASKET: GRAPHITE PACKING: GRAPHITE	
	VALVE SELECTION	--		ADAMS SERIES MAK	
CHECK VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		BUTTWELD ENDS	
	CONSTRUCTION	BODY/CAP: A105 (BOLTED) SWING CHECK SEAT RING: 316 HF DISC: 13% CR GASKET: SPIRAL WOUND		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SW701 BONNEY FORGE FIG. H61SW		POWELL FIGURE 3061 CRANE FIGURE 159-1/2 BONNEY FORGE 3-61 BW	
BALL VALVE	CONNECTION AND RATING	CLASS 900 PSIG SOCKETWELD		--	
	CONSTRUCTION	BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CHROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER		--	
	VALVE SELECTION	VELAN TYPE R, METAL SEATED, CLASS 900		--	
GLOBE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		BUTTWELD ENDS	
	CONSTRUCTION	BODY/BONNET: A105 (BOLTED) (BODY HARDFACED) DISC: 420SST TRIM: 13% Cr STEM: A183 F6A PACKING: GRAPHITE GASKET: SPIRAL WOUND SST WITH GRAPHITE		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SW12141 BONNEY FORGE FIG. H31SW		POWELL FIGURE 3031 CRANE FIGURE 151-1/2 BONNEY FORGE 3-31 BW	
REVISION HISTORY					
NUMBER	DESCRIPTION		DATE		
0	INITIAL ISSUE		2/22/2021		

LOW PRESSURE CONDENSATE (TO 50 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-LP-CON	PIPE SIZE (NPS)	LOW PRESSURE CONDENSATE		50 PSIG AT 340 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 24"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	A106 GRADE B - SEAMLESS		A106 GRADE B - SEAMLESS	
	CONSTRUCTION	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
FITTINGS:	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
PIPING JOINTS:	TYPE	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
	OTHER	WHERE FLANGE OR THREAD REQUIRED		WHERE FLANGE REQUIRED	
UNIONS:	CONSTRUCTION	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN		NOT PERMITTED	
	WALL THICKNESS	SAME AS ADJOINING PIPE		--	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		--	
FLANGES:	CONSTRUCTION	CLASS 150 - WELD NECK - ASME B16.5			
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		FORGED CARBON STEEL - ASTM A105	
FLANGE BOLTS:	CONSTRUCTION	ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7			
FLANGE NUTS:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H			
WASHER:	CONSTRUCTION	F436			
GASKETS:	CONSTRUCTION	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES			
	MATERIAL	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER			
THERMOWELLS:	CONSTRUCTION	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS			
	MATERIAL	ASTM A106 CARBON STEEL			
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1		0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
	CARBON STEEL	150 PSIG	ASME B31.1	ASME B16.34	
UI-LP-CON	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 24"	
GATE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD (1" THRU 2")		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105, TRIM 13% CR OUTSIDE SCREW & YOKE, BOLTED GLAND, SOLID WEDGE, HARD FACED SEATS, CLASS 800 PACKING: GRAPHITE		BODY/BONNET: A216 GR. WCB SEAT RING: HARDFACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SS WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12111 BONNEY FORGE FIG. H11SW		POWELL FIGURE 1503 CRANE FIGURE 47 BONNEY FORGE 1-11 RF	
BUTTERFLY VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/BONNET: A216 GR. WCB SEAT RING: METAL SEAT DISC: A351 CF8M SHAFT: 17-4 PH PACKING: PTFE GLAND: 304 SS	
	VALVE SELECTION	--		POWELL FIGURE 1572 DEZURIK STYLE BHP FLOWSEAL TYPE 1LA	
CHECK VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY/CAP: A105 (BOLTED) SWING CHECK SEAT RING: STELLITE 6 FACED 410 SS DISC: 13% CR GASKET: SPIRAL WOUND		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SW701 BONNEY FORGE FIG. H61SW		POWELL FIGURE 1561 CRANE FIGURE 147 BONNEY FORGE 1-61 RF	
BALL VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS (UP TO 6")	
	CONSTRUCTION	BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER		BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER (GEAR OPERATOR OVER 4")	
	VALVE SELECTION	VELAN TYPE R, METAL SEATED, CLASS 900		VELAN TYPE R	
GLOBE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105 (BOLTED) (BODY HARDFACED) DISC: 420SST TRIM: 13% Cr STEM: A183 F6A PACKING: GRAPHITE GASKET: SPIRAL WOUND SST WITH GRAPHITE		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SW12141 BONNEY FORGE FIG. H31SW		POWELL FIGURE 1531 CRANE FIGURE 143 BONNEY FORGE 1-31 RF	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
0	INITIAL ISSUE			2/22/2021	

HIGH PRESSURE CONDENSATE (TO 175 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-HP-CON	PIPE SIZE (NPS)	HIGH PRESSURE CONDENSATE		175 PSIG AT 500 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 24"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	A106 GRADE B - SEAMLESS		A106 GRADE B - SEAMLESS	
	CONSTRUCTION	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
FITTINGS:	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM 105		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
PIPING JOINTS:	TYPE	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
	OTHER	WHERE FLANGE OR THREAD REQUIRED		WHERE FLANGE REQUIRED	
UNIONS:	CONSTRUCTION	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN		NOT PERMITTED	
	WALL THICKNESS	SAME AS ADJOINING PIPE		--	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		--	
FLANGES:	CONSTRUCTION	CLASS 300 - WELD NECK - ASME B16.5			
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		FORGED CARBON STEEL - ASTM A105	
FLANGE BOLTS:	CONSTRUCTION	ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7, STUD - FULL LENGTH			
FLANGE NUTS:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H			
WASHER:	CONSTRUCTION	F436			
GASKETS:	CONSTRUCTION	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES			
	MATERIAL	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER			
THERMOWELLS:	CONSTRUCTION	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS			
	MATERIAL	ASTM A106 CARBON STEEL			
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1		4	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
	CARBON STEEL	300 PSIG	ASME B31.1	ASME B16.34	
UI-HP-CON	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 24"	
GATE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105, TRIM 13% CR OUTSIDE SCREW & YOKE, BOLTED GLAND, SOLID WEDGE, HARD FACED SEATS, CLASS 800 PACKING: GRAPHITE		BODY/BONNET: A105 OR A216 GR. WCB SEAT RING: HARDFACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: SPIRAL WOUND SS WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12111 BONNEY FORGE FIG. H11SW		POWELL FIGURE 3003 CRANE FIGURE 33-1/2 BONNEY FORGE 3-11 RF	
BUTTERFLY VALVE	CONNECTION AND RATING	--		CLASS 300 FLANGED ENDS (LUG STYLE)	
	CONSTRUCTION	--		BODY/BONNET: A217 GR. WC6 SEAT RING: A182 F11; STELLITE 6 FACED DISC/WEDGE: A217 GR. WC6; STELLITE 6 FACED STEM: 410 SS PACKING: GRAPHITE GASKET: SPIRAL WOUND SS WITH GRAPHITE	
	VALVE SELECTION	--		POWELL FIGURE 3072 (3" AND LARGER) FLOWSEAL METAL SEAT CLASS 300	
CHECK VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/CAP: A105 (BOLTED) SWING CHECK SEAT RING: 316 HF DISC: 13% CR GASKET: SPIRAL WOUND		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SW701 BONNEY FORGE FIGURE H61SW		POWELL FIGURE 3061 CRANE FIGURE 159-1/2 BONNEY FORGE 3-61 RF	
BALL VALVE	CONNECTION AND RATING	CLASS 900 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER		BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER (GEAR OPERATOR OVER 4")	
	VALVE SELECTION	VELAN TYPE R, METAL SEATED, CLASS 900		VELAN TYPE R	
GLOBE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105 (BOLTED) (BODY HARDFACED) DISC: 420SST TRIM: 13% Cr STEM: A183 F6A PACKING: GRAPHITE GASKET: SPIRAL WOUND SST WITH GRAPHITE		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SW12141 BONNEY FORGE FIG. H31SW		POWELL FIGURE 3031 CRANE FIGURE 151-1/2 BONNEY FORGE 3-31 RF	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
1	CHANGED SMALL BORE VALVES TO CLASS 800 FROM CLASS 3000			6/30/2017	
2	ADDED WALL THICKNESS TO TABLE, REMOVED OTHER REFERENCES TO WALL THICKNESS			9/22/2017	
3	CHANGED UNIONS TO A FLAT-FACED GASKETED DESIGN			11/22/2017	
4	UPDATED LARGE BORE WALL THICKNESS; VALVE SELECTIONS			2/22/2021	

HOT WATER SUPPLY/RETURN (TO 245 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-HW	PIPE SIZE (NPS)	HOT WATER SUPPLY/RETURN		245 PSIG AT 250 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 24"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	XS		STD	
	CONSTRUCTION	A106 GRADE B - SEAMLESS		A106 GRADE B - SEAMLESS	
FITTINGS:	WALL THICKNESS	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
	MATERIAL	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
PIPING JOINTS:	TYPE	FORGED CARBON STEEL - ASTM A105		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
	OTHER	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
UNIONS:	CONSTRUCTION	WHERE FLANGE OR THREAD REQUIRED		WHERE FLANGE REQUIRED	
	WALL THICKNESS	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN		NOT PERMITTED	
FLANGES:	MATERIAL	SAME AS ADJOINING PIPE		--	
	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105		--	
FLANGE BOLTS:	CONSTRUCTION	CLASS 150 - WELD NECK - ASME B16.5		SAME AS ADJOINING PIPE	
FLANGE NUTS:	CONSTRUCTION	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
WASHER:	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105		FORGED CARBON STEEL - ASTM A105	
GASKETS:	CONSTRUCTION	ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7			
	MATERIAL	HEAVY HEX - A194 GRADE 2H			
THERMOWELLS:	CONSTRUCTION	F436			
	MATERIAL	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES			
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1		0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-HW	CARBON STEEL	150 PSIG	ASME B31.1	ASME B16.34	
GATE VALVE	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 24"	
	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS	
BUTTERFLY VALVE	CONSTRUCTION	BODY/BONNET: A105, TRIM 13% CR OUTSIDE SCREW & YOKE, BOLTED GLAND, SOLID WEDGE, HARD FACED SEATS, CLASS 800 PACKING: GRAPHITE		BODY/BONNET: A216 GR. WCB SEAT RING: HARDFACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SS WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12111 BONNEY FORGE FIG. H11SW		POWELL FIGURE 1503 CRANE FIGURE 47 BONNEY FORGE 1-11 RF	
CHECK VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/BONNET: A216 GR. WCB SEAT RING: METAL SEAT DISC: A351 CF8M SHAFT: 17-4 PH PACKING: PTFE GLAND: 304 SS	
BALL VALVE	VALVE SELECTION	--		POWELL FIGURE 1572 DEZURIK STYLE BHP FLOWSEAL TYPE 1LA	
	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS	
GLOBE VALVE	CONSTRUCTION	BODY/CAP: A105 (BOLTED) SWING CHECK SEAT RING: STELLITE 6 FACED 410 SS DISC: 13% CR GASKET: SPIRAL WOUND		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SW701 BONNEY FORGE FIG. H61SW		POWELL FIGURE 1561 CRANE FIGURE 147 BONNEY FORGE 1-61 RF	
REVISION HISTORY	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS (UP TO 6")	
	CONSTRUCTION	BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER		BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER (GEAR OPERATOR OVER 4")	
REVISION HISTORY	VALVE SELECTION	VELAN TYPE R, METAL SEATED, CLASS 900		VELAN TYPE R	
	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS	
REVISION HISTORY	CONSTRUCTION	BODY/BONNET: A105 (BOLTED) (BODY HARDFACED) DISC: 420SST TRIM: 13% Cr STEM: A183 F6A PACKING: GRAPHITE GASKET: SPIRAL WOUND SST WITH GRAPHITE		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SW12141 BONNEY FORGE FIG. H31SW		POWELL FIGURE 1531 CRANE FIGURE 143 BONNEY FORGE 1-31 RF	
NUMBER	DESCRIPTION		DATE		
0	INITIAL ISSUE		2/22/2021		

RELIEF DEVICE VENT PIPING

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:	
UI-VENT		RELIEF DEVICE VENT PIPING	250 PSIG AT 500 °F	
	PIPE SIZE (NPS)	2" AND SMALLER	2 1/2" THRU 24"	
PIPE MATERIAL: ASME B36.10M	WEIGHT/SCHEDULE	XS	STD	
	MATERIAL	A106 GRADE B - SEAMLESS	A106 GRADE B - SEAMLESS	
FITTINGS:	CONSTRUCTION	CLASS 3000 - SOCKETWELD - B16.11	BUTTWELD - ASME B16.9	
	WALL THICKNESS	SAME AS ADJOINING PIPE	SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM A105	BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
PIPING JOINTS:	TYPE	SOCKETWELD	BUTTWELD - END PREP PER B16.25	
	OTHER	WHERE FLANGE OR THREAD REQUIRED	WHERE FLANGE REQUIRED	
UNIONS:	CONSTRUCTION	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN	NOT PERMITTED	
	WALL THICKNESS	SAME AS ADJOINING PIPE	--	
	MATERIAL	FORGED CARBON STEEL - ASTM A105	--	
FLANGES:	CONSTRUCTION	CLASS 300 - WELD NECK - ASME B16.5		
	WALL THICKNESS	SAME AS ADJOINING PIPE	SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM A105	FORGED CARBON STEEL - ASTM A105	
FLANGE BOLTS:	CONSTRUCTION	ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7, STUD - FULL LENGTH		
FLANGE NUTS:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H		
WASHER:	CONSTRUCTION	F436		
GASKETS:	CONSTRUCTION	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES		
	MATERIAL	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER		
THERMOWELLS:	CONSTRUCTION	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS		
	MATERIAL	ASTM A106 CARBON STEEL		
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1	0	2/22/2021
FINISH:	SPECIFICATION MATERIAL:	2-COAT SYSTEM WITH SOLVENT-BASED INORGANIC ZINC PRIMER, AND INORGANIC SILICATE POLYMER TOP COAT - REFER TO PROJECT SPECIFICATIONS COLOR TO MATCH RED OF EXISTING RELIEF DEVICE PIPING		

REVISION HISTORY		
NUMBER	DESCRIPTION	DATE
0	INITIAL ISSUE	2/22/2021

EQUIPMENT DRAIN PIPING

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-ED	PIPE SIZE (NPS)	EQUIPMENT DRAINS		250 PSIG AT 500 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 24"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	A106 GRADE B - SEAMLESS		A106 GRADE B - SEAMLESS	
	CONSTRUCTION	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
FITTINGS:	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM a 105		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
PIPING JOINTS:	TYPE	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
	OTHER	WHERE FLANGE OR THREAD REQUIRED		WHERE FLANGE REQUIRED	
UNIONS:	CONSTRUCTION	CLASS 3000 - SW - B16.11 - FLAT- FACE WITH SPIRAL WOUND GASKET DESIGN		NOT PERMITTED	
	WALL THICKNESS	SAME AS ADJOINING PIPE		--	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		--	
FLANGES:	CONSTRUCTION	CLASS 300 - WELD NECK - ASME B16.5			
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		FORGED CARBON STEEL - ASTM A105	
FLANGE BOLTS:	CONSTRUCTION	ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7, STUD - FULL LENGTH			
FLANGE NUTS:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H			
WASHER:	CONSTRUCTION	F436			
GASKETS:	CONSTRUCTION	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES			
	MATERIAL	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER			
THERMOWELLS:	CONSTRUCTION	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS			
	MATERIAL	ASTM A106 CARBON STEEL			
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1		0	2/22/2021
FINISH:	SPECIFICATION MATERIAL:	REFER TO PROJECT SPECIFICATION PAINT EQUIPMENT DRAIN PIPING WHITE			
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-ED	CARBON STEEL	300 PSIG	ASME B31.1	ASME B16.34	
	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 24"	
GATE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105, TRIM 13% CR OUTSIDE SCREW & YOKE, BOLTED GLAND, SOLID WEDGE, HARD FACED SEATS, CLASS 800 PACKING: GRAPHITE		BODY/BONNET: A105 OR A216 GR. WCB SEAT RING: HARDFACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: SPIRAL WOUND SS WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12111 BONNEY FORGE FIG. H11SW		POWELL FIGURE 3003 CRANE FIGURE 33-1/2 BONNEY FORGE 3-11 RF	
BUTTERFLY VALVE	CONNECTION AND RATING	--		CLASS 300 FLANGED ENDS (LUG STYLE)	
	CONSTRUCTION	--		BODY/BONNET: A217 GR. WCB SEAT RING: A182 F11; STELLITE 6 FACED DISC/WEDGE: A217 GR. WCB; STELLITE 6 FACED STEM: 410 SS PACKING: GRAPHITE GASKET: SPIRAL WOUND SS WITH GRAPHITE	
	VALVE SELECTION			POWELL FIGURE 3072* (3" AND LARGER) FLOWSEAL METAL SEAT CLASS 300	
CHECK VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/CAP: A105 (BOLTED) SWING CHECK SEAT RING: 316 HF DISC: 13% CR GASKET: SPIRAL WOUND		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SW701 BONNEY FORGE FIG. H61SW		POWELL FIGURE 3061 CRANE FIGURE 159-1/2 BONNEY FORGE 3-61 RF	
BALL VALVE	CONNECTION AND RATING	CLASS 900 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER		BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER (GEAR OPERATOR OVER 4")	
	VALVE SELECTION	VELAN TYPE R, METAL SEATED, CLASS 900		VELAN TYPE R	
GLOBE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105 (BOLTED) (BODY HARDFACED) DISC: 420SST TRIM: 13% Cr STEM: A183 F6A PACKING: GRAPHITE GASKET: SPIRAL WOUND SST WITH GRAPHITE		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SW12141 BONNEY FORGE FIG. H31SW		POWELL FIGURE 3031 CRANE FIGURE 151-1/2 BONNEY FORGE 3-31 RF	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
0	INITIAL ISSUE			2/22/2021	

BOILER FEEDWATER (TO 250 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-FW	PIPE SIZE (NPS)	BOILER FEEDWATER		250 PSIG AT 300 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 10"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	A106 GRADE B - SEAMLESS		A106 GRADE B - SEAMLESS	
	CONSTRUCTION	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
FITTINGS:	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
PIPING JOINTS:	TYPE	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
	OTHER	INSERTION THERMOWELLS - ASTM A105 - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS			
UNIONS:	CONSTRUCTION	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN		NOT PERMITTED	
	WALL THICKNESS	SAME AS ADJOINING PIPE		--	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		--	
FLANGES:	CONSTRUCTION	CLASS 300 - WELD NECK - ASME B16.5			
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		FORGED CARBON STEEL - ASTM A105	
FLANGE BOLTS:	CONSTRUCTION	STUD - FULL-LENGTH ASME B1.1 - CLASS 2A THREADS			
FLANGE NUTS:	CONSTRUCTION	HEAVY HEX - ASME B1.1 - CLASS 2B THREADS			
GASKETS:	CONSTRUCTION	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES			
	MATERIAL	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER			
THERMOWELLS:	CONSTRUCTION	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS			
	MATERIAL	ASTM A106 CARBON STEEL			
PIPE MATERIAL: CARBON STEEL	PIPE CODE:	DESIGN/CONSTRUCTION CODE: ASME B31.1		REVISION: 0	DATE REVISED: 2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL: CARBON STEEL	PRESSURE CLASS: 300 PSIG	DESIGN CODE: ASME B31.1	DESIGN CODE: ASME B16.34	
UI-FW	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 10"	
GATE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105, TRIM 13% CR OUTSIDE SCREW & YOKE, BOLTED GLAND, SOLID WEDGE, HARD FACED SEATS, CLASS 800 PACKING: GRAPHITE		BODY/BONNET: A105 OR A216 GR. WCB SEAT RING: HARDFACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: SPIRAL WOUND SS WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12111 BONNEY FORGE FIG. H11SW		POWELL FIGURE 3003 CRANE FIGURE 33-1/2 BONNEY FORGE 3-11 RF	
BUTTERFLY VALVE	CONNECTION AND RATING	--		CLASS 300 FLANGED - LUG STYLE	
	CONSTRUCTION	--		BODY/BONNET: A217 GR. WC6 SEAT RING: A182 F11; STELLITE 6 FACED DISC/WEDGE: A217 GR. WC6; STELLITE 6 FACED STEM: 410 SS PACKING: GRAPHITE GASKET: SPIRAL WOUND SS WITH GRAPHITE	
	VALVE SELECTION	--		POWELL FIGURE 3072* (3" AND LARGER) FLOWSEAL METAL SEAT CLASS 300	
CHECK VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/CAP: A105 (BOLTED) SWING CHECK SEAT RING: 316 HF DISC: 13% CR GASKET: SPIRAL WOUND		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SW701 BONNEY FORGE FIG. H61SW		POWELL FIGURE 3061 CRANE FIGURE 159-1/2 BONNEY FORGE 3-61 RF	
BALL VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		--	
	CONSTRUCTION	BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER		--	
	VALVE SELECTION	VELAN TYPE R, METAL SEATED, CLASS 900		--	
GLOBE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105 (BOLTED) (BODY HARDFACED) DISC: 420SST TRIM: 13% Cr STEM: A183 F6A PACKING: GRAPHITE GASKET: SPIRAL WOUND SST WITH GRAPHITE		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SW12141 BONNEY FORGE FIG. H31SW		POWELL FIGURE 3031 CRANE FIGURE 151-1/2 BONNEY FORGE 3-31 RF	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
0	INITIAL ISSUE			2/22/2021	

NATURAL GAS (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:	
UI-GFS	PIPE SIZE (NPS)	NATURAL GAS	150 PSIG AT 150 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER	2-1/2" THRU 10"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	XS	STD	
	CONSTRUCTION	ASTM A53 GRADE B, SEAMLESS	ASTM A53 GRADE B, SEAMLESS	
FITTINGS:	WALL THICKNESS	CLASS 3000 SOCKET WELD - ASME B16.11	BUTT WELD - ASME B16.25	
	MATERIAL	SAME AS ADJOINING PIPE	SAME AS ADJOINING PIPE	
PIPING JOINTS:	TYPE	FORGED CARBON STEEL - ASTM A105	BUTT WELD FITTING - ASTM A234, GR. B SEAMLESS	
	OTHER	SOCKET WELD	BUTT WELD - END PREP PER ASME B16.25	
UNIONS:	CONSTRUCTION	INSERTION THERMOWELLS - ASTM A105 - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS	NOT PERMITTED	
	WALL THICKNESS	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN	--	
FLANGES:	MATERIAL	SAME AS ADJOINING PIPE	--	
	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105	CLASS 150 - WELD NECK - ASME B16.5	
FLANGE BOLTS:	CONSTRUCTION	SAME AS ADJOINING PIPE	SAME AS ADJOINING PIPE	
FLANGE NUTS:	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105	FORGED CARBON STEEL - ASTM A105 - STD WT	
WASHER:	CONSTRUCTION	ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7	HEAVY HEX - A194 GRADE 2H	
GASKETS:	CONSTRUCTION	F436	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1/NFPA 54	3	2/22/2021
FINISH:	SPECIFICATION MATERIAL:	REFER TO PROJECT SPECIFICATION - PAINT NATURAL GAS PIPING SAFETY YELLOW		
VALVE SPECIFICATION	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE	
UI-GFS	CARBON STEEL	150 PSIG	ASME B31.1	ASME B16.34
	PIPE SIZE (NPS)	2" AND SMALLER	2-1/2" THRU 10"	
BALL VALVE	CONNECTION AND RATING	CLASS 150 FLANGED ENDS		
	CONSTRUCTION	BODY: A216 WCB BALL AND STEM: TYPE 316 STAINLESS STEEL SEATS: RTFE OR NYLON WITH SEAT RING AND GASKET SEALS: TFE FIRE-SAFE OPERATOR: LEVER HANDLE BLOWOUT PROOF PACKING ANTI-STATIC GROUNDING SPRING		
VALVE SELECTION	JAMESBURY SERIES 7150 KECKLEY BVF1 VELAN TYPE R			
PLUG VALVE	CONNECTION AND RATING	--	CLASS 150 RAISED FACE FLANGED ENDS	
	CONSTRUCTION	--	BODY/BONNET: A105 OR A216 GR WCB COVER, GLAND: CARBON STEEL PLUG: CARBON STEEL STEM: CARBON STEEL PACKING: GRAPHITE/TFE COMPOUND GASKET: SS WITH GRAPHITE	
VALVE SELECTION	--	NORDSTROM FIGURE 1925 (THRU 4"); FIGURE 1945 (6"-8"); FIGURE 1949 (10")		

REVISION HISTORY		
NUMBER	DESCRIPTION	DATE
1	ADDED WALL THICKNESS TO TABLE, REMOVED OTHER REFERENCES TO WALL THICKNESS	9/22/2017
2	CHANGED UNIONS TO A FLAT-FACED GASKETED DESIGN	11/22/2017
3	UPDATED VALVE SELECTIONS; ADDED PIPE FINISH SPECIFICATION	2/22/2021

COMPRESSED AIR SYSTEMS (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-AIR	PIPE SIZE (NPS)	COMPRESSED AIR/INSTRUMENT AIR		150 PSIG AT 150 °F	
	WEIGHT/SCHEDULE	4" AND SMALLER (NOTE 1)		2-1/2" THRU 24" (NOTE 1)	
PIPE MATERIAL: ASME B36.10M/B88	MATERIAL	ASTM B88 COPPER, TYPE L, HARD DRAWN		ASTM A106 GRADE B - SEAMLESS (NON-BLACK STEEL)	
FITTINGS:	CONSTRUCTION	SOLDERED OR PRESS FIT		BUTTWELD	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	ASME B16.18 CAST COPPER OR ASME B16.22 WROUGHT COPPER ALLOY		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
PIPING JOINTS:	TYPE	SOLDERED OR PRESS FIT		BUTTWELD - END PREP PER B16.25	
	OTHER	SEE BELOW FOR JOINT DETAILS		--	
SOLDER/FLANGES:	CONSTRUCTION	SOLDER: ASTM B32 ALLOY, GRADE Sb-5 95/5 TIN-ANTIMONY, LEAD FREE OR: ASTM B32 ALLOY, GRADE SN95 TIN-SILVER, LEAD FREE		CLASS 150 - WELD NECK - ASME B16.5	
	WALL THICKNESS			SAME AS ADJOINING PIPE	
	MATERIAL			FORGED STEEL - ASTM A105	
SOLDER/FLANGE BOLTS:	CONSTRUCTION	SOLDER: FILLER METAL LEAD-FREE - WATER-FLUSHABLE FLUX ASTM B813 - SILVER BRAZING FILLER METAL SHALL BE BCuP SERIES, COPPER PHOSPHORUS ALLOYS FOR GENERAL DUTY BRAZING - AWS A5.8		STUD - FULL-LENGTH ASME B1.1	
	MATERIAL			HIGH-STRENGTH STEEL - ASTM A193 - GRADE B7, FULL LENGTH STUD	
PRESS FIT/FLANGE NUTS:	CONSTRUCTION			HEAVY HEX - ASME B1.1 - CLASS 2B THREADS	
	MATERIAL	PRESS FIT: MATERIALS CONFORM TO ASME B16.18 OR: ASME B16.22 AND CRITERIA UNDER IAPMO PS 117 - SEALING ELEMENTS: EPDM - SEALING ELEMENTS FACTORY INSTALLED - FITTINGS SHALL BE PRESSED BY TOOLS RECOMMENDED BY FITTING MANUFACTURER		CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS	
PRESS FIT/GASKETS:	CONSTRUCTION			SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
	MATERIAL			TYPE 304 SS - FULL FACE - FLEXITALLIC FLEXICARB STYLE CGI OR EQUAL	
UNIONS:	CONSTRUCTION	THREADED		NOT PERMITTED	
	MATERIAL	SAME AS ADJOINING PIPE			
	OTHER	INSTALL UNIONS: IN LONG RUNS AT 80' INTERVALS - IN BYPASS OF VALVES/EQUIPMENT - AT EQUIPMENT CONNECTIONS			
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
COPPER/CARBON STEEL	ASME B36.10M/B88	ASME B31.1		3	2/22/2021
FINISH:	SPECIFICATION MATERIAL:	DO NOT PAINT COPPER AIR PIPING		REFER TO PROJECT SPECIFICATION PAINT COMPRESSED AIR PIPING WHITE	
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-AIR	AS NOTED	150 PSIG	ASME B31.1	ASME B16.34	
	PIPE SIZE (NPS)	4" AND SMALLER (NOTE 1)		2 1/2" THRU 24" (NOTE 1)	
GATE VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/BONNET: A216 GR. WCB SEAT RING: STELLITE 6 FACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SS WITH GRAPHITE	
	VALVE SELECTION	--		POWELL FIGURE 1503 CRANE FIGURE 47 BONNEY FORGE 1-11 RF	
BUTTERFLY VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED - LUG STYLE	
	CONSTRUCTION	--		BODY/BONNET: A216 GR. WCB SEAT RING: PTFE/RTFE/UHMWPE DISC: A351 CF8M SHAFT: 17-4 PH PACKING: PTFE GLAND: 304 SS	
	VALVE SELECTION	--		POWELL FIGURE 1572 JAMESBURY SERIES 815 FLOWSEAL TYPE 1LA	
CHECK VALVE	CONNECTION AND RATING	CLASS 200 PSIG THREADED OR SOLDERED		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: BRONZE DISC: BRONZE SEAT DISC: BUNA-N HINGE PIN AND PLUG: BRONZE ASTM B140 ALLOY DISC HANGER: SAME AS BODY		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARD FACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	NIBCO 433 SERIES APOLLO 161S SERIES (THRU 2")		POWELL FIGURE 1561 CRANE FIGURE 147 BONNEY FORGE 1-61 RF	
BALL VALVE	CONNECTION AND RATING	CLASS 600 PSIG THREADED OR SOLDERED		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY: CAST BRONZE OR BRASS, FULL PORT BALL: CHROME PLATED BRONZE OR BRASS STEM: BRONZE OR BRASS SEATS/SEALS: RPTFE PACKING: RPTFE LOCKABLE, QUARTER TURN LEVER HANDLE		BODY/BONNET: A105 OR WCB (BOLTED) SEAT RING: MPTE/PTFE/RPTFE BALL AND STEM: SS 316 PACKING: PTFE AND GRAPHITE BODY SEAL: SS 316 GRAPHITE LOCKING LEVER (3" AND SMALLER) LOCKING GEAR OPERATOR (4" AND LARGER)	
	VALVE SELECTION	APOLLO 70-200 SERIES MILWAUKEE BA-485B NIBCO S-FP-600A SERIES		VELAN UB-150 JAMESBURY SERIES 7000 KECKLEY BVF1	

NOTES:

1) EITHER COPPER OR CARBON STEEL PIPE MATERIAL MAY BE USED FOR PIPE SIZES BETWEEN 2-1/2" AND 4". FINAL PIPE MATERIAL SHALL BE SELECTED BASED UPON THE INDIVIDUAL PROJECT NEEDS. DESIGN PROFESSIONAL SHALL COORDINATE SELECTION OF PIPE MATERIAL WITH UTILITY OPERATOR.

REVISION HISTORY		
NUMBER	DESCRIPTION	DATE
1	ADDED WALL THICKNESS TO TABLE, REMOVED OTHER REFERENCES TO WALL THICKNESS	9/22/2017
2	ADDED 'FINISH' SPECIFICATION	10/10/2019
3	UPDATED VALVE SELECTIONS; INCREASED UPPER LIMIT FOR COPPER PIPE SIZE TO 4" AND ADDED OVERLAP SIZE RANGE	2/22/2021

MAKEUP WATER AND POTABLE WATER (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-MUS-PWS	PIPE SIZE (NPS)	MAKEUP AND POTABLE WATER		150 PSIG AT 150 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 24"	
PIPE MATERIAL:	MATERIAL	SCH 40S		SCH 10S	
ASME B36.10M	CONSTRUCTION	A312 TYPE 304 - SEAMLESS OR WELDED		A312 GRADE 304 - SEAMLESS OR WELDED	
FITTINGS:	WALL THICKNESS	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
	MATERIAL	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
PIPING JOINTS:	TYPE	FORGED STEEL - ASTM A182, F304L, ASME B16.25		ASTM A403, WP304L - SEAMLESS, B16.25	
	OTHER	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
FLANGES:	CONSTRUCTION	UNIONS: CLASS 3000 - SW - B16.11 - FLAT-FACE WITH SPIRAL WOUND GASKET DESIGN		WHERE FLANGE REQUIRED	
	WALL THICKNESS	FLANGES NOT PERMITTED		CLASS 150 PSIG	
FLANGE BOLTS:	MATERIAL	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	CONSTRUCTION	--		SS, ASTM A182, F330L, ASME B16.5	
FLANGE NUTS:	CONSTRUCTION	--		HIGH-STRENGTH STAINLESS STEEL, GRADE B8, CLASS 2, STUD - FULL LENGTH	
WASHER:	CONSTRUCTION	--		HEAVY HEX - A194 GRADE 8	
GASKETS:	CONSTRUCTION	--		SS304	
	MATERIAL	--		SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
THERMOWELLS:	CONSTRUCTION	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS		FULL FACE - 1/16" ARAMID FIBER WITH SBR BINDER - GARLOCK BLUE-GARD OR EQUAL	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
STAINLESS STEEL	ASTM B36.10M	ASME B31.1		6	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-MUS-PWS	STAINLESS STEEL	150 PSIG	ASME B31.1	ASME B16.34	
GATE VALVE	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 24"	
	CONNECTION AND RATING	CLASS 800 SOCKETWELD		CLASS 150 FLANGED ENDS	
BUTTERFLY VALVE	CONSTRUCTION	BODY: ASTM A182 F316 BONNET: ASTM A182 F316 DISC: ASTM A182 F316 STEM: ASTM A182 F316 PACKING: PTFE		BODY: ASTM A351 CF8M BONNET: ASTM A351 CF8M DISC: ASTM A351 CF8M STEM: ASTM A276 T316 PACKING: PTFE	
	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12401 BONNEY FORGE HL-18-SW		POWELL FIGURE 1503 CRANE FIGURE 47 (THRU 24") BONNEY FORGE 1-18 RF	
CHECK VALVE	CONNECTION AND RATING	--		CLASS 150 PSIG FLANGED ENDS	
	CONSTRUCTION	--		BODY: A182 GR. F316 OR A351 GR. CF8M SEAT: TFE/VITON DISC: A182 GR. F316 OR A351 GR. CF8M SHAFT: 17-4 PH PACKING: TFE	
BALL VALVE	VALVE SELECTION	--		POWELL FIGURE 1572 CRANE FLOWSEAL TYPE 1LA (12" AND SMALLER) TYPE 1LC (14" AND LARGER) JAMESBURY SERIES 815	
	CONNECTION AND RATING	CLASS 800 SOCKETWELD		CLASS 150 FLANGED ENDS (2-1/2" THRU 12")	
GLOBE VALVE	CONSTRUCTION	BODY/CAP: A182 F316L CARRIER/CARRIER PIN: 316SS DISC: A276 T316 SEAT RING: 316 SST GASKET: SPIRAL WOUND SST WITH PTFE		BODY: ASTM A351 GR. CF8M CAP: ASTM A351 GR. CF8M CARRIER/CARRIER PIN: 316SS DISC: ASTM A351 GR. CF8M GASKET: PTFE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SERIES SWS718 BONNEY FORGE HL-68-SW		POWELL FIGURE 1561 CRANE FIGURE 147 (THRU 24") BONNEY FORGE 1-68 RF	
GLOBE VALVE	CONNECTION AND RATING	CLASS 800 SOCKETWELD		CLASS 150 FLANGED ENDS (2-1/2" THRU 20")	
	CONSTRUCTION	BODY/BONNET: ASTM A351, CF8M STAINLESS STEEL, FULL-PORT SEAT RING: XTREME BALL: SS 316 SEAL: PTFE PACKING: GRAPHITE		BODY/INSERT: A351 CF8M BALL: 316 SS STEM: 316 SS SEAT: PTFE BODY SEAL: TFM STEM SEAL: PTFE	
GLOBE VALVE	VALVE SELECTION	JAMESBURY SERIES 4000 MODEL A KECKLEY SYTE BVM3 KITZ U3TZM		JAMESBURY SERIES 7150 KECKLEY BVF1 (THRU 6") VELAN SB-150	
	CONSTRUCTION	CLASS 800 SOCKETWELD		CLASS 150 FLANGED ENDS (2 1/2" THRU 12")	
GLOBE VALVE	CONSTRUCTION	BODY: ASTM A182 F316 BONNET: ASTM A182 F316 DISC: ASTM A182 F316 STEM: ASTM A182 F316 PACKING: PTFE		BODY: ASTM A351 CF8M BONNET: ASTM A351 CF8M DISC: ASTM A351 CF8M STEM: ASTM A276 T316 PACKING: PTFE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SERIES SW12501 BONNEY FORGE HL-38-SW		POWELL FIGURE 1531 CRANE FIGURE 143 (THRU 24") BONNEY FORGE 1-38 RF	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
1	CHANGED SMALL BORE VALVES TO CLASS 800 FROM CLASS 3000			6/30/2017	
2	ADDED WALL THICKNESS TO TABLE, REMOVED OTHER REFERENCES TO WALL THICKNESS			9/22/2017	
3	CHANGED SMALL BORE BALL VALVES TO JAMESBURY FROM KECKLEY			11/15/2017	
4	CHANGED UNIONS TO A FLAT-FACED GASKETED DESIGN			11/22/2017	
5	CHANGED SMALL BORE CHECK VALVES TO SWING CHECKS RATHER THAN BALL CHECKS			2/27/2018	
6	UPDATED VALVE SELECTIONS			2/22/2021	

SANITARY/STORM SEWER/VENT

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-SEW		SANITARY SEWER, SEWER VENT, STORM		15 PSIG AT 140 °F	
PIPE SIZE (NPS)		4" AND SMALLER		ALL SIZES	
PIPE MATERIAL:		WEIGHT/SCHEDULE		SERVICE WEIGHT	
COPPER/CAST IRON		-		CAST IRON, ASTM A74	
MATERIAL		ASTM B306, DWV		CAST IRON CISPI 301 OR ASTM A-888	
CONSTRUCTION		SOLDERED OR PRESS FIT		BELL AND SPIGOT	
FITTINGS:		MATERIAL		HUBLESS	
		ASME B16.23 CAST BRONZE OR ASME B16.29 WROUGHT COPPER		CAST IRON, ASTM A74	
JOINTS:		ABOVE GRADE TYPE		ASTM C564, RUBBER GASKETS JOINT DEVICES OR LEAD AND OAKUM	
		SOLDERED OR PRESS FIT		CISPI 310 NEOPRENE GASKETS AND STAINLESS STEEL CLAMP AND SHIELD ASSEMBLIES	
SOLDER/BURIED TYPE		SOLDER: ASTM B32 ALLOY, GRADE Sb-5 95/5 TIN-ANTIMONY, LEAD FREE OR: ASTM B32 ALLOY, GRADE SN95 TIN-SILVER, LEAD FREE		HUB AND SPIGOT, CISPI HSN COMPRESSION TYPE WITH ASTM C564 NEOPRENE GASKETS OR LEAD AND OAKUM	
NOTES:		1) THIS SPECIFICATION IS INTENDED FOR MAIN DRAIN AND VENT LINES WITHIN THE POWER AND CHILLED WATER PLANTS ON MAIN CAMPUS AND OAKDALE CAMPUS. FOLLOW THE UNIVERSITY OF IOWA DESIGN STANDARDS AND PROCEDURES FOR BUILDING PLUMBING SYSTEMS (I.E. RESTROOMS, KITCHEN AREAS, ETC.) WITHIN THESE PLANTS. 2) EITHER COPPER OR CAST IRON PIPE MATERIAL MAY BE USED FOR PIPE SIZES BETWEEN 4" AND SMALLER. FINAL PIPE MATERIAL SHALL BE SELECTED BASED UPON THE INDIVIDUAL PROJECT NEEDS. DESIGN PROFESSIONAL SHALL COORDINATE SELECTION OF PIPE MATERIAL WITH UTILITY OPERATOR. 3) PROVIDE TRAPS ON ALL SANITARY BRANCH WASTE CONNECTIONS FROM FIXTURES WITHOUT TRAPS 4) EXPOSED BRASS SHALL BE CHROME-PLATED POLISHED BRASS WITH NIPPLE AND SET SCREW ESCUTCHEONS 5) CONCEALED TRAPS MAY BE ROUGH CAST BRASS OR SAME MATERIAL AS PIPE CONNECTED TO 6) SLIP JOINTS NOT ALLOWED ON SEWER SIDE OF TRAP 7) TRAPS SHALL CORRESPOND TO FITTINGS ON CAST IRON SOIL PIPE OR STEEL PIPE 8) SIZE SHALL BE AS REQUIRED BY CONNECTED SERVICE OR FIXTURE			
PIPE MATERIAL:		PIPE CODE		TYPE	
COPPER/CAST IRON		ASTM B306/A74		PRESS FIT, SOLDER, BELL AND SPIGOT OR HUBLESS	
VALVE SPECIFICATION:		SPECIFICATION MATERIAL:		REVISION:	
UI-SEW		CAST IRON		2	
CONNECTION AND RATING		PRESSURE CLASS:		DATE REVISION:	
GATE VALVE		125 PSIG OR 150 PSIG		2/22/2021	
CONSTRUCTION		DESIGN CODE:			
VALVE SELECTION		125 PSIG OR 150 PSIG		ASME B31.1 / ASME B16.34	
CONNECTION AND RATING		PER ADJOINING PIPING SPECIFICATIONS			
CONSTRUCTION		BODY: CAST IRON COVER: CAST IRON HANDWHEEL: CAST IRON (REMOVABLE) GATE FLAPPER: BRONZE EXTENSIONS: CAST IRON			
VALVE SELECTION		POWELL FIGURE 1787 (2" THRU 24") MILWAUKEE SERIES F-2882 CRANE F53			
CONNECTION AND RATING		PER ADJOINING PIPING SPECIFICATIONS			
CONSTRUCTION		BODY/BONNET: ASTM A126 CAST IRON BODY BEARING: SS 316 PACKING: PTFE HANDWHEEL: CAST IRON (REMOVABLE) PLUG: SS 316 EXTENSIONS: CAST IRON			
STANDARD		ANSI/AWWA C517			
VALVE SELECTION		DEZURIK PEC SERIES OR EQUAL BY MILLIKEN			

CARBON STEEL:		
NUMBER	DESCRIPTION	DATE
1	INITIAL ISSUE	4/14/2017
2	UPDATED VALVE SELECTIONS; ADDED COPPER DWV PIPING AS AN OPTION FOR SMALLER SIZES	2/22/2021

BOILER BLOWOFF/BLOWDOWN (TO 250 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-BOS-BDS	PIPE SIZE (NPS)	BLOWOFF/BLOWDOWN SYSTEM		250 PSIG AT 400 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 10"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	XS		XS	
	CONSTRUCTION	A106 GRADE B - SEAMLESS		A106 GRADE B - SEAMLESS	
FITTINGS:	WALL THICKNESS	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
	MATERIAL	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
PIPING JOINTS:	MATERIAL	FORGED CARBON STEEL - ASTM 105		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
	TYPE	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
UNIONS:	OTHER	--		--	
	CONSTRUCTION	CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN		NOT PERMITTED	
FLANGES:	WALL THICKNESS	SAME AS ADJOINING PIPE		--	
	MATERIAL	FORGED CARBON STEEL - ASTM A105		--	
FLANGE BOLTS:	CONSTRUCTION	CLASS 300 - WELD NECK - ASME B16.5		--	
	MATERIAL	SAME AS ADJOINING PIPE		--	
FLANGE NUTS:	CONSTRUCTION	FORGED CARBON STEEL - ASTM A105		--	
	MATERIAL	STUD - FULL LENGTH ASME B1.1 - CLASS 2A THREADS		--	
GASKETS:	CONSTRUCTION	HIGH STRENGTH STEEL - ASTM A193 - GRADE B7		--	
	MATERIAL	HEAVY HEX - ASME B1.1 - CLASS 2B THREADS		--	
THERMOWELLS:	CONSTRUCTION	CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS		--	
	MATERIAL	SPIRAL WOUND - SUITABLE FOR RAISED FACE OR FLAT FACE FLANGES		--	
PIPE MATERIAL: CARBON STEEL	CONSTRUCTION	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER		--	
	MATERIAL	INSERTION THERMOWELLS - 3000 PSIG PRESSURE CLASS - SEAL WELDED WELLS		--	
VALVE SPECIFICATION:	CONSTRUCTION	ASTM A105 CARBON STEEL		--	
	MATERIAL	ASTM A105 CARBON STEEL		--	
UI-BOS-BDS	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	
	ASTM B36.10M	ASME B31.1		0	
PIPE MATERIAL: CARBON STEEL	SPECIFICATION MATERIAL:	PRESSURE CLASS:		DATE REVISED:	
	CARBON STEEL	300 PSIG		2/22/2021	
UI-BOS-BDS	DESIGN CODE:	ASME B31.1		ASME B16.34	
	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 10"	
GATE VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD (1" THRU 2")		CLASS 300 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: A105, TRIM 13% CR OUTSIDE SCREW & YOKE, BOLTED GLAND, SOLID WEDGE, HARD FACED SEATS, CLASS 800 PACKING: GRAPHITE		BODY/BONNET: A105 OR A216 GR. WCB SEAT RING: HARDFACED DISC/WEDGE: A217 GR. CA15 OR WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: SPIRAL WOUND SS WITH GRAPHITE	
CHECK VALVE	VALVE SELECTION	POWELL FIGURE GA08 VOGT SW12111 BONNEY FORGE FIG. H11SW		POWELL FIGURE 3003 CRANE FIGURE 33-1/2 BONNEY FORGE 3-11 RF	
	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
BALL VALVE	CONSTRUCTION	BODY/CAP: A105 (BOLTED) SWING CHECK SEAT RING: 316 HF DISC: 13% CR GASKET: SPIRAL WOUND		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SW701 BONNEY FORGE FIG. H61SW		POWELL FIGURE 3061 CRANE FIGURE 159-1/2 BONNEY FORGE 3-61 RF	
GLOBE VALVE	CONNECTION AND RATING	CLASS 900 PSIG SOCKETWELD		--	
	CONSTRUCTION	BODY: A105, STEM SS 410 COND. 2 THRUST WASHER: STELLITE 6; BALL AND SEAT: SS 410/CHROME CARBIDE COATED; STEM: SS 410; THRUST BUSHING: BRONZE; PACKING FLANGE SS 304 STEM BUSHING: NITRIDED SS410 COND. 2; SEAT SS 410 COND.2 CHROME CARBIDE COATED LOCKABLE LEVER		--	
GLOBE VALVE	VALVE SELECTION	VELAN TYPE R, METAL SEATED, CLASS 900		--	
	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 300 FLANGED ENDS	
GLOBE VALVE	CONSTRUCTION	BODY/BONNET: A105 (BOLTED) (BODY HARDFACED) DISC: 420SST TRIM: 13% Cr STEM: A183 F6A PACKING: GRAPHITE GASKET: SPIRAL WOUND SST WITH GRAPHITE		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	POWELL FIGURE GL08 VOGT SW12141 BONNEY FORGE FIG. H31SW		POWELL FIGURE 3031 CRANE FIGURE 151-1/2 BONNEY FORGE 3-31 RF	

NOTES:

REVISION HISTORY		
NUMBER	DESCRIPTION	DATE
0	INITIAL ISSUE	2/22/2021

CHILLED WATER (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-CHW	PIPE SIZE (NPS)	CHILLED WATER		150 PSIG AT 100 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 30"	36" THRU 48"
PIPE MATERIAL:	MATERIAL	--		STD	STD
ASME B36.10M/B88	MATERIAL	ASTM B88 COPPER, TYPE L, HARD DRAWN		A53 OR A106 GRADE B - SEAMLESS	API 5L GRADE B - SEAMLESS
FITTINGS:	CONSTRUCTION	SOLDERED OR PRESS FIT		BUTTWELD - ASME B16.9	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	ASME B16.18 CAST COPPER OR ASME B16.22 WROUGHT COPPER ALLOY		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
PIPING JOINTS:	TYPE	SOLDERED OR PRESS FIT		BUTTWELD - END PREP PER B16.25	
	OTHER	SEE BELOW FOR JOINT DETAILS		--	
SOLDER/FLANGES:	CONSTRUCTION	SOLDER: ASTM B32 ALLOY, GRADE Sb-5 95/5 TIN-ANTIMONY, LEAD FREE OR: ASTM B32 ALLOY, GRADE SN95 TIN-SILVER, LEAD FREE		CLASS 150 - WELD NECK - ASME B16.47 AND B16.5	
	WALL THICKNESS			SAME AS ADJOINING PIPE	
	MATERIAL			FORGED STEEL - ASTM A105 OR ASTM A516 GRADE 70	
SOLDER/FLANGE BOLTS:	CONSTRUCTION	SOLDER: FILLER METAL LEAD-FREE - WATER-FLUSHABLE FLUX ASTM B813 - SILVER BRAZING FILLER METAL SHALL BE BCuP SERIES, COPPER PHOSPHORUS ALLOYS FOR GENERAL DUTY BRAZING - AWS A5.8		ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7	
	MATERIAL			HIGH-STRENGTH STEEL - ASTM A193 - GRADE B7, FULL LENGTH STUD	
PRESS FIT/FLANGE NUTS:	CONSTRUCTION			HEAVY HEX - ASME B1.1 - CLASS 2B THREADS	
	MATERIAL	PRESS FIT: MATERIALS CONFORM TO ASME B16.18 OR: ASME B16.22 AND CRITERIA UNDER IAPMO PS 117 - SEALING ELEMENTS: EPDM - SEALING ELEMENTS FACTORY INSTALLED - FITTINGS SHALL BE PRESSED BY TOOLS RECOMMENDED BY FITTING MANUFACTURER		CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS	
PRESS FIT/GASKETS:	CONSTRUCTION			SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
	MATERIAL			TYPE 304 SS - FULL FACE - FLEXITALLIC FLEXICARB STYLE CGI OR EQUAL	
WASHER:	CONSTRUCTION	--		CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
COPPER/CARBON STEEL	ASME B36.10M/B88	ASME B31.1		0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-CHW	AS NOTED	150 PSIG	ASME B31.1	ASME B16.34	
BUTTERFLY VALVE	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 48"	
	CONNECTION AND RATING	--		LUGGED FOR CLASS 150 FLANGES	
	CONSTRUCTION	--		BODY/SEAT: CARBON STEEL STEM: SS DISC: SS GLAND/BEARING: SS WITH RTFE IMPREGNATED OPERATOR: GEARED HANDWHEEL W/ POSITION INDICATOR SEAT: PTFE 200 PSIG WORKING PRESSURE	
VALVE SELECTION	--		ABZ SERIES 400 DEZURIK STYLE BHP JAMESBURY SERIES 815		
CHECK VALVE	CONNECTION AND RATING	CLASS 600 PSIG THREADED OR SOLDERED		CLASS 150 FLANGED ENDS (2 1/2" THRU 24")	
	CONSTRUCTION	BODY/BONNET: BRONZE DISC: BRONZE SEAT DISC: BUNA-N HINGE PIN AND PLUG: BRONZE ASTM B140 ALLOY DISC HANGER: SAME AS BODY		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	NIBCO 433 SERIES APOLLO 161S SERIES		POWELL FIGURE 1561 CRANE FIGURE 147 BONNEY FORGE 1-61 RF	
SILENT CHECK VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/CAP: CAST OR FORGED ASTM A216 GRADE WCB CARBON STEEL SEAT: STAINLESS STEEL DISC OR PLUG: TYPE 316 STAINLESS STEEL STEM: STAINLESS STEEL TORSION SPRING: TYPE 316 STAINLESS STEEL GASKET: SPIRAL WOUND SS WITH GRAPHITE 12" THRU 42": GLOBE 10" AND SMALLER: WAFER	
	VALVE SELECTION	--		KECKLEY CO. MODEL CG (GLOBE) OR CW (WAFER) MUELLER MODEL 101MDT OR 105MDT DEZURIK STYLE CSC	
BALL VALVE	CONNECTION AND RATING	CLASS 600 PSIG THREADED OR SOLDERED		--	
	CONSTRUCTION	BODY: BRONZE, 2-PIECE, FULL-PORT BALL: SS 316 STEM: STAINLESS STEEL, BLOWOUT PROOF PACKING: PTFE SEATS AND SEALS: REINFORCED PTFE		--	
	VALVE SELECTION	APOLLO 77-140 SERIES NIBCO MODEL T-580-70-66 MILWAUKEE 20BS SERIES		--	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
1	CHANGED SMALL BORE VALVES TO CLASS 600 FROM CLASS 3000			6/30/2017	
2	ADDED SPECIFICATIONS FOR PIPE SIZES 36" THRU 48", CHANGED SMALL BORE BALL VALVE MODEL			2/22/2021	

CONDENSER WATER - DI (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:	
UI-CS-DI	PIPE SIZE (NPS)	CONDENSER WATER	150 PSIG at 150 °F	
	WEIGHT/SCHEDULE		3" THRU 48"	
PIPE MATERIAL: ANSI/AWWA C151/A21.51	MATERIAL	SPECIAL THICKNESS CLASS 53 ANSI/AWWA C150/A21.50		
	CONSTRUCTION	ANSI/AWWA C151/A21.51 DUCTILE IRON PIPING		
FITTINGS:	DESIGN RATING	ANSI/AWWA C110/A21.10 FLANGED		
	MATERIAL	150 PSIG IN ACCORDANCE WITH ANSI/AWWA C110/A21.10 DUCTILE IRON		
JOINTS:	TYPE	ANSI/AWWA C115/A21.15 FLANGED		
	DESIGN RATING	250 PSIG IN ACCORDANCE WITH ANSI/AWWA C115/A21.15		
SERVICE SADDLES:	OTHER	-		
	CONSTRUCTION	ASTM A536 DUCTILE IRON		
	DESIGN RATING	350 PSIG IN ACCORDANCE WITH ANSI/AWWA C800		
	COATING	FUSION BONDED BLACK NYLON		
FLANGES:	STRAPS	TYPE 304 STAINLESS STEEL		
	CONSTRUCTION	CLASS 150 - WELD NECK - ASME B16.5		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
BOLTS:	MATERIAL	FORGED CARBON STEEL - ASTM A105		
	CONSTRUCTION	STAINLESS STEEL IN ACCORDANCE WITH ASTM A240		
NUTS:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H		
WASHERS:	CONSTRUCTION	TYPE 304 STAINLESS STEEL		
GASKETS:	CONSTRUCTION	SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES AND FOR USE WITH SERVICE SADDLES		
	STANDARD	ANSI/AWWA C111/A21.11		
	MATERIAL	FULL FACE - 1/16" ARAMID FIBER WITH SBR BINDER - GARLOCK BLUE-GARD OR EQUAL		
PIPE LINING:	CONSTRUCTION	CEMENT MORTAR LINING AND SEAL COAT		
	STANDARD	ANSI/AWWA C104/A21.4		
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:	DATE REVISED:
DUCTILE IRON	ANSI/AWWA C151/A21.51	--	0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:	
UI-CS-DI	DUCTILE IRON	--	--	--
	PIPE SIZE (NPS)		3" THRU 48"	
BUTTERFLY VALVE	CONNECTION AND RATING	LUGGED FOR CLASS 150 FLANGES		
	CONSTRUCTION	BODY/SEAT: CARBON STEEL STEM: SS DISC: SS GLAND/BEARING: SS WITH RTFE IMPREGNATED OPERATOR: GEARED HANDWHEEL W/ POSITION INDICATOR SEAT: PTFE 200 PSIG WORKING PRESSURE		
	VALVE SELECTION	ABZ SERIES 400 DEZURIK STYLE BHP JAMESBURY SERIES 815		
REVISION HISTORY				
NUMBER	DESCRIPTION	DATE		
0	INITIAL ISSUE	1/5/2018		
1	ADDED INFORMATION FOR BUTTERFLY VALVE	2/22/2021		

CONDENSER WATER - COPPER AND CARBON STEEL (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-CS-CS	PIPE SIZE (NPS)	CONDENSER WATER		150 PSIG AT 150 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 30"	36" THRU 48"
PIPE MATERIAL:	MATERIAL	ASTM B88 COPPER, TYPE L, HARD DRAWN		STD	STD
ASME B36.10M/B88	MATERIAL	ASTM B88 COPPER, TYPE L, HARD DRAWN		A53 OR A106 GRADE B - SEAMLESS	API 5L GRADE B - SEAMLESS
FITTINGS:	CONSTRUCTION	SOLDERED OR PRESS FIT		BUTTWELD - ASME B16.9	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	ASME B16.18 CAST COPPER OR ASME B16.22 WROUGHT COPPER ALLOY		BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS	
PIPING JOINTS:	TYPE	SOLDERED OR PRESS FIT		BUTTWELD - END PREP PER B16.25	
	OTHER	SEE BELOW FOR JOINT DETAILS			
SOLDER/FLANGES:	CONSTRUCTION	SOLDER: ASTM B32 ALLOY, GRADE Sb-5 95/5 TIN-ANTIMONY, LEAD FREE OR: ASTM B32 ALLOY, GRADE SN95 TIN-SILVER, LEAD FREE		CLASS 150 - WELD NECK - ASME B16.47 AND B16.5	
	WALL THICKNESS			SAME AS ADJOINING PIPE	
	MATERIAL			FORGED STEEL - ASTM A105 OR ASTM A516 GRADE 70	
SOLDER/FLANGE BOLTS:	CONSTRUCTION	SOLDER: FILLER METAL LEAD-FREE - WATER-FLUSHABLE FLUX ASTM B813 - SILVER BRAZING FILLER METAL SHALL BE BCuP SERIES, COPPER PHOSPHORUS ALLOYS FOR GENERAL DUTY BRAZING - AWS A5.8		ALLOY STEEL, AISI 4140/4142 QUENCHED AND TEMPERED, A193 GRADE B7	
	MATERIAL			HIGH-STRENGTH STEEL - ASTM A193 - GRADE B7, FULL LENGTH STUD	
PRESS FIT/FLANGE NUTS:	CONSTRUCTION			HEAVY HEX - ASME B1.1 - CLASS 2B THREADS	
	MATERIAL	PRESS FIT: MATERIALS CONFORM TO ASME B16.18 OR: ASME B16.22 AND CRITERIA UNDER IAPMO PS 117 - SEALING ELEMENTS: EPDM - SEALING ELEMENTS FACTORY INSTALLED - FITTINGS SHALL BE PRESSED BY TOOLS RECOMMENDED BY FITTING MANUFACTURER		CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS	
PRESS FIT/GASKETS:	CONSTRUCTION			SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
	MATERIAL			TYPE 304 SS - FULL FACE - FLEXITALLIC FLEXICARB STYLE CGI OR EQUAL	
WASHER:	CONSTRUCTION	--		CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
COPPER/CARBON STEEL	ASME B36.10M/B88	ASME B31.1		0	2/22/2021
FINISH:	SPECIFICATION MATERIAL:	3-COAT SYSTEM WITH EPOXY PRIMER, ACRYLIC INTERMEDIATE COAT AND POLYURETHANE TOP COAT COLOR TO MATCH GRAY OF EXISTING CONDENSER WATER PIPING - FOR UNINSULATED CONDENSER WATER PIPING			
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-CS-CS	AS NOTED	150 PSIG	ASME B31.1	ASME B16.34	
	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 48"	
	CONNECTION AND RATING	--		LUGGED FOR CLASS 150 FLANGES	
BUTTERFLY VALVE	CONSTRUCTION	--		BODY/SEAT: CARBON STEEL STEM: SS DISC: SS GLAND/BEARING: SS WITH RTFE IMPREGNATED OPERATOR: GEARED HANDWHEEL W/ POSITION INDICATOR SEAT: PTFE 200 PSIG WORKING PRESSURE	
	VALVE SELECTION	--		ABZ SERIES 400 DEZURIK STYLE BHP JAMESBURY SERIES 815	
CHECK VALVE	CONNECTION AND RATING	CLASS 600 PSIG THREADED OR SOLDERED		CLASS 150 FLANGED ENDS (2 1/2" THRU 24")	
	CONSTRUCTION	BODY/BONNET: BRONZE DISC: BRONZE SEAT DISC: BUNA-N HINGE PIN AND PLUG: BRONZE ASTM B140 ALLOY DISC HANGER: SAME AS BODY		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	NIBCO 433 SERIES APOLLO 161S SERIES		POWELL FIGURE 1561 CRANE FIGURE 147 BONNEY FORGE 1-61 RF	
SILENT CHECK VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/CAP: CAST OR FORGED ASTM A216 GRADE WCB CARBON STEEL SEAT: STAINLESS STEEL DISC OR PLUG: TYPE 316 STAINLESS STEEL STEM: STAINLESS STEEL TORSION SPRING: TYPE 316 STAINLESS STEEL GASKET: SPIRAL WOUND SS WITH GRAPHITE 12" THRU 42": GLOBE 10" AND SMALLER: WAFER	
	VALVE SELECTION	--		KECKLEY CO. MODEL CG (GLOBE) OR CW (WAFER) MUELLER MODEL 101MDT OR 105MDT DEZURIK STYLE CSC	
BALL VALVE	CONNECTION AND RATING	CLASS 600 PSIG THREADED OR SOLDERED		--	
	CONSTRUCTION	BODY: BRONZE, 2-PIECE, FULL-PORT BALL: SS 316 STEM: STAINLESS STEEL, BLOWOUT PROOF PACKING: PTFE SEATS AND SEALS: REINFORCED PTFE		--	
	VALVE SELECTION	APOLLO 77-140 SERIES NIBCO MODEL T-580-70-66 MILWAUKEE 20BS SERIES		--	
GLOBE VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS (2 1/2" THRU 24")	
	CONSTRUCTION	--		BODY/BONNET: A216 GR. WCB (BOLTED) SEAT RING: A105 OR A216 HARDFACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY STEM: 410 SS PACKING: GRAPHITE GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	--		CRANE FIGURE 143 POWELL FIGURE 1531 VELAN FIGURE 0074C	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
0	INITIAL ISSUE			2/22/2021	

CONDENSER WATER - SS (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-CS-SS	PIPE SIZE (NPS)	CONDENSER WATER		150 PSIG AT 150 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 48"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	SCH 40S		SCH 10S	
	MATERIAL	A312 TYPE 304 - SEAMLESS		A312 TYPE 304 - SEAMLESS OR WELDED	
FITTINGS:	CONSTRUCTION	SOCKETWELD: CLASS 3000, B16.11 THREADED: CLASS 2000, B16.11		BUTTWELD - ASME B16.9	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	ASTMA403, WP304L - SEAMLESS, B16.25		ASTM A403, WP304L - SEAMLESS, B16.25	
JOINTS:	TYPE	SOCKETWELD CLASS 3000 OR THREADED CLASS 2000		BUTTWELD - END PREP PER B16.25	
	OTHER	UNIONS: CLASS 3000 - SW - B16.11 - FLAT FACE WITH SPIRAL WOUND GASKET DESIGN		WHERE FLANGE REQUIRED	
FLANGES:	CONSTRUCTION	FLANGES NOT PERMITTED		CLASS 150 - WELD NECK - ASME B16.47 AND B16.5	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	--		SS, ASTM A182, F330L, ASME B16.5	
FLANGE BOLTS:	CONSTRUCTION	--		HIGH-STRENGTH STAINLESS STEEL, GRADE B8, CLASS 2, STUD - FULL LENGTH	
FLANGE NUTS:	CONSTRUCTION	--		HEAVY HEX - A194 GRADE 8	
WASHER:	CONSTRUCTION	--		SSS304	
GASKETS:	CONSTRUCTION	--		SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
	MATERIAL	--		FULL FACE - 1/16" ARAMID FIBER WITH SBR BINDER - GARLOCK BLUE-GARD OR EQUAL	
PIPE MATERIAL: STAINLESS STEEL	PIPE CODE: ASME B36.10M	DESIGN/CONSTRUCTION CODE: ASME B31.1		REVISION: 0	DATE REVISED: 2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL: CARBON STEEL	PRESSURE CLASS: 150 PSIG	DESIGN CODE: ASME B31.1	DESIGN CODE: ASME B16.34	
UI-CS-SS	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 48"	
BUTTERFLY VALVE	CONNECTION AND RATING	--		LUGGED FOR CLASS 150 FLANGES	
	CONSTRUCTION	--		BODY: A182 GR. F316 OR A351 GR. CF8M SEAT: TFE/VITON DISC: A182 GR. F316 OR A351 GR. CF8M SHAFT: 17-4 PH PACKING: TFE	
	VALVE SELECTION	--		POWELL FIGURE 1572 CRANE FLOWSEAL TYPE 1LA (12" AND SMALLER) TYPE 1LC (14" AND LARGER) JAMESBURY SERIES 815	
CHECK VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS (2-1/2" THRU 12")	
	CONSTRUCTION	BODY/CAP: A182 F316L CARRIER/CARRIER PIN: 316SS DISC: A276 T316 SEAT RING: 316 SST GASKET: SPIRAL WOUND SST WITH PTFE		BODY: ASTM A351 GR. CF8M CAP: ASTM A351 GR. CF8M CARRIER/CARRIER PIN: 316SS DISC: ASTM A351 GR. CF8M GASKET: PTFE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SERIES SWS718 BONNEY FORGE HL-68-SW		POWELL FIGURE 1561 CRANE FIGURE 147 (THRU 24") BONNEY FORGE 1-68 RF	
SILENT CHECK VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/CAP: CAST STAINLESS STEEL ASTM A351 GR. CF8M SEAT: CAST STAINLESS STEEL, ASTM A351 GR. CF8M DISC OR PLUG: CAST STAINLESS STEEL, ASTM A351 GR. CF8M STEM: STAINLESS STEEL SPRING: TYPE 316 STAINLESS STEEL GASKET: SPIRAL WOUND SS WITH GRAPHITE 12" THRU 42": GLOBE 10" AND SMALLER: WAFER	
	VALVE SELECTION	--		KECKLEY CO. MODEL CG (GLOBE) OR CW (WAFER) MUELLER MODEL 101MDT OR 105MDT DEZURIK STYLE CSC	
BALL VALVE	CONNECTION AND RATING	CLASS 800 PSIG SOCKETWELD		CLASS 150 FLANGED ENDS (2-1/2" THRU 20")	
	CONSTRUCTION	BODY/BONNET: ASTM A351, CF8M STAINLESS STEEL, FULL-PORT SEAT RING: XTREME BALL: SS 316 SEAL: PTFE PACKING: GRAPHITE		BODY/INSERT: A351 CF8M BALL: 316 SS STEM: 316 SS SEAT: PTFE BODY SEAL: TFM STEM SEAL: PTFE GEAR OPERATOR 4" AND LARGER	
	VALVE SELECTION	JAMESBURY SERIES 4000 MODEL A KECKLEY SYTE BVM3 KITZ U3TZM		JAMESBURY SERIES 7150 KECKLEY BV/F1 (THRU 6") VELAN SB-150	
GLOBE VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS (2 1/2" THRU 24")	
	CONSTRUCTION	--		BODY: ASTM A351 CF8M BONNET: ASTM A351 CF8M DISC: ASTM A351 CF8M STEM: ASTM A276 T316 PACKING: PTFE	
	VALVE SELECTION	--		POWELL FIGURE 1531 CRANE FIGURE 143 (THRU 24") BONNEY FORGE 1-38 RF	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
0	INITIAL ISSUE			2/22/2021	

**CONDENSER WATER
DRAINS (TO 150 PSIG)**

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-CS-DRAIN	PIPE SIZE (NPS)	CONDENSER WATER		150 PSIG AT 120 °F	
	WEIGHT/SCHEDULE			2"	
PIPE MATERIAL: ASME B36.10M	MATERIAL	ASTM B88 COPPER, TYPE K, HARD DRAWN			
	CONSTRUCTION	SOLDERED OR PRESS FIT			
FITTINGS:	WALL THICKNESS	SAME AS ADJOINING PIPE			
	MATERIAL	ASME B16.18 CAST COPPER OR ASME B16.22 WROUGHT COPPER ALLOY			
PIPING JOINTS:	TYPE	SOLDERED OR PRESS FIT			
	OTHER	SEE BELOW FOR JOINT DETAILS			
SOLDER:	MATERIAL	SOLDER: ASTM B32 ALLOY, GRADE SB-5 95/5 TIN-ANTIMONY, LEAD FREE OR: ASTM B32 ALLOY, GRADE SN95 TIN-SILVER, LEAD FREE			
		SOLDER: FILLER METAL LEAD-FREE - WATER-FLUSHABLE FLUX ASTM B813 - SILVER BRAZING FILLER METAL SHALL BE BCuP SERIES, COPPER PHOSPHORUS ALLOYS FOR GENERAL DUTY BRAZING - AWS A5.8			
PRESS FIT:	CONSTRUCTION	PRESS FIT: MATERIALS CONFORM TO ASME B16.18 OR: ASME B16.22 AND CRITERIA UNDER IAPMO PS 117 - SEALING ELEMENTS: EPDM - SEALING ELEMENTS FACTORY INSTALLED - FITTINGS SHALL BE PRESSED BY TOOLS RECOMMENDED BY FITTING MANUFACTURER			
	MATERIAL				
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
COPPER	ASTM B88	ASME B31.1		0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
	AS NOTED	150 PSIG	ASME B31.1	ASME B16.34	
UI-CS-DRAIN	PIPE SIZE (NPS)	2"			
CHECK VALVE	CONNECTION AND RATING	CLASS 200 PSIG THREADED			
	CONSTRUCTION	BODY/CAP: ASTM B584 BRONZE DISC: BRONZE, SWING TYPE, Y-PATTERN SEAT: BRASS SPRING: SS 316			
	VALVE SELECTION	APOLLO 161T-LF SERIES POWELL MSS SP-80 NIBCO T-413-Y-LF			
BALL VALVE	CONNECTION AND RATING	CLASS 600 PSIG THREADED			
	CONSTRUCTION	BODY: BRONZE, 2-PIECE, FULL-PORT BALL: SS 316 STEM: STAINLESS STEEL, BLOWOUT PROOF PACKING: RPTFE SEATS AND SEALS: RPTFE			
	VALVE SELECTION	APOLLO 77-140 SERIES NIBCO MODEL T-580-70-66 MILWAUKE 20BS SERIES			
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
0	INITIAL ISSUE			2/22/2021	

PROCESS WATER - INTERIOR (TO 135 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-PCW (CS)	PIPE SIZE (NPS)	PROCESS WATER		135 PSIG at 200 °F	
	WEIGHT/SCHEDULE	4" AND SMALLER		2 1/2" THRU 24"	
PIPE MATERIAL: ASME B36.10M/B88	MATERIAL	ASTM B88 COPPER, TYPE L, HARD DRAWN		ASTM A106 GRADE B SEAMLESS (NON-BLACK STEEL)	
FITTINGS:	CONSTRUCTION	SOLDERED OR PRESS FIT		BUTT WELD - ASME B16.25	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	ASME B16.18 CAST COPPER OR ASME B16.22 WROUGHT COPPER ALLOY		BUTT WELD FITTING - ASTM A234 GRADE B - SEAMLESS	
JOINTS:	TYPE	SOLDERED OR PRESS FIT		BUTT WELD - END PREP PER B16.25	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	OTHER	SEE BELOW FOR JOINT DETAILS		--	
SOLDER/FLANGES:	CONSTRUCTION	SOLDER: ASTM B32 ALLOY, GRADE Sb-5 95/5 TIN-ANTIMONY, LEAD FREE OR: ASTM B32 ALLOY, GRADE SN95 TIN-SILVER, LEAD FREE		CLASS 150 - WELD NECK - ASME B16.5	
	WALL THICKNESS			SAME AS ADJOINING PIPE	
	MATERIAL			FORGED CARBON STEEL - ASTM A105	
SOLDER/FLANGE BOLTS:	CONSTRUCTION	SOLDER: FILLER METAL LEAD-FREE - WATER-FLUSHABLE FLUX ASTM B813 - SILVER BRAZING FILLER METAL SHALL BE BCuP SERIES, COPPER PHOSPHORUS ALLOYS FOR GENERAL DUTY BRAZING - AWS A5.8		STUD - FULL-LENGTH ASME B1.1	
	MATERIAL			HIGH-STRENGTH STEEL - ASTM A193 - GRADE B7, FULL LENGTH STUD	
PRESS FIT/FLANGE NUTS:	CONSTRUCTION			HEAVY HEX - ASME B1.1 - CLASS 2B THREADS	
	MATERIAL	PRESS FIT: MATERIALS CONFORM TO ASME B16.18 OR: ASME B16.22 AND CRITERIA UNDER IAPMO PS 117 - SEALING ELEMENTS: EPDM - SEALING ELEMENTS FACTORY INSTALLED - FITTINGS SHALL BE PRESSED BY TOOLS RECOMMENDED BY FITTING MANUFACTURER		CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS	
PRESS FIT/GASKETS:	CONSTRUCTION			SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
	MATERIAL			TYPE 304 SS - FULL FACE - FLEXITALLIC FLEXICARB STYLE CGI OR EQUAL	
WASHER:	CONSTRUCTION	--		CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS	
UNIONS:	CONSTRUCTION	THREADED		NOT PERMITTED	
	MATERIAL	SAME AS ADJOINING PIPE			
	OTHER	INSTALL UNIONS: IN LONG RUNS AT 80' INTERVALS - IN BYPASS OF VALVES/EQUIPMENT - AT EQUIPMENT CONNECTIONS			
PIPE MATERIAL: COPPER/CARBON STEEL	PIPE CODE: ASME B36.10M/B88	DESIGN/CONSTRUCTION CODE: ASME B31.1		REVISION: 2	DATE REVISED: 2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL: AS NOTED	PRESSURE CLASS: 150 PSIG	DESIGN CODE: ASME B31.1	ASME B16.34	
UI-PCW (CS)	PIPE SIZE (NPS)	4" AND SMALLER		2 1/2" THRU 24"	
GATE VALVE	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/BONNET: ASTM A395 CAST IRON, OS&Y SEATS AND SEALS: ASTM B61 BRONZE DISC/WEDGE: BRONZE STEM: ASTM B16 BRASS PACKING: ARAMID FIBERS WITH GRAPHITE	
	VALVE SELECTION	--		APOLLO 610F-LFA SERIES OR EQUAL BY POWELL OR NIBCO	
BUTTERFLY VALVE	CONNECTION AND RATING	--		LUGGED FOR CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY/SEAT: DUCTILE IRON SHAFT: SS DISC: STAINLESS STEEL SEAT: EPDM GLAND/BEARING: BRONZE OR ALUMINIZED BRONZE OPERATOR: GEARED HANDWHEEL W/ POSITION INDICATOR 200 PSIG WORKING PRESSURE	
	VALVE SELECTION	--		DEZURIK BOS-US OR JAMESBURY SERIES 815	
CHECK VALVE	CONNECTION AND RATING	CLASS 600 PSIG THREADED OR SOLDERED		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	BODY/BONNET: BRONZE DISC: BRONZE SEAT DISC: BUNA-N HINGE PIN AND PLUG: BRONZE ASTM B140 ALLOY DISC HANGER: SAME AS BODY		BODY/CAP: A216 GR. WCB (BOLTED) SEAT RING: HARD FACED DISC: A105 OR A216 WCB WITH 13% CR OVERLAY GASKET: CORRUGATED SST WITH GRAPHITE	
	VALVE SELECTION	NIBCO 433 SERIES APOLLO 161S SERIES (THRU 2")		POWELL FIGURE 1561 CRANE FIGURE 147 BONNEY FORGE 1-61 RF	
BALL VALVE	CONNECTION AND RATING	CLASS 600 PSIG THREADED OR SOLDERED		CLASS 150 FLANGED ENDS (UP TO 6")	
	CONSTRUCTION	BODY: CAST BRONZE OR BRASS, FULL PORT BALL: CHROME PLATED BRONZE OR BRASS STEM: BRONZE OR BRASS SEATS/SEALS: RPTFE PACKING: RPTFE LOCKABLE, QUARTER TURN LEVER HANDLE		BODY/BONNET: A105 OR WCB (BOLTED) SEAT RING: MPTFE/PTFE/RPTFE BALL AND STEM: SS 316 PACKING: PTFE AND GRAPHITE BODY SEAL: SS 316 GRAPHITE GEAR OPERATOR 4" AND LARGER	
	VALVE SELECTION	APOLLO 70-200 SERIES MILWAUKEE BA-485B NIBCO S-FP-600A SERIES		VELAN UB-150 JAMESBURY SERIES 7000 KECKLEY BVF1	
NOTES:					
1) EITHER COPPER OR CARBON STEEL PIPE MATERIAL MAY BE USED FOR PIPE SIZES BETWEEN 2-1/2" AND 4". FINAL PIPE MATERIAL SHALL BE SELECTED BASED UPON THE INDIVIDUAL PROJECT NEEDS. DESIGN PROFESSIONAL SHALL COORDINATE SELECTION OF PIPE MATERIAL WITH UTILITY OPERATOR.					
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
1	CHANGED SMALL BORE VALVES TO CLASS 600 FROM CLASS 3000			6/30/2017	
2	ADDED ADDITIONAL VALVE MANUFACTURERS; INCREASED SMALL BORE UPPER LIMIT TO 4", ALLOWED SIZE RANGE OVERLAP			2/22/2021	

PROCESS WATER - EXTERIOR (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-PCW (SS)	PIPE SIZE (NPS)	PROCESS WATER - EXTERIOR 2" AND SMALLER		150 PSIG AT 100 °F 2 1/2" THRU 24"	
	PIPE MATERIAL: ASME B36.10M	WEIGHT/SCHEDULE	SCH 40S	SCH 10S	
FITTINGS:	MATERIAL	A312 TYPE 304 - SEAMLESS OR WELDED		A312 GRADE 304 - SEAMLESS OR WELDED	
	CONSTRUCTION	CLASS 3000 - SOCKETWELD - B16.11		BUTTWELD - ASME B16.9	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
PIPING JOINTS:	MATERIAL	FORGED STEEL - ASTM A182, F304L, ASME B16.25		ASTM A403, WP304L - SEAMLESS, B16.25	
	TYPE	SOCKETWELD		BUTTWELD - END PREP PER B16.25	
	OTHER	UNIONS: CLASS 3000 - SW - B16.11 - FLAT-FACE WITH SPIRAL WOUND GASKET DESIGN		--	
FLANGES:	CONSTRUCTION	FLANGES NOT PERMITTED		CLASS 150 - WELD NECK - ASME B16.47 AND B16.5	
	WALL THICKNESS	--		SAME AS ADJOINING PIPE	
	MATERIAL	--		SS, ASTM A182, F330L, ASME B16.5	
FLANGE BOLTS:	CONSTRUCTION	--		HIGH-STRENGTH STAINLESS STEEL, GRADE B8, CLASS 2, STUD - FULL LENGTH	
FLANGE NUTS:	CONSTRUCTION	--		HEAVY HEX - A194 GRADE 8	
WASHER:	CONSTRUCTION	--		SS304	
GASKETS:	CONSTRUCTION	--		SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
	MATERIAL	--		FULL FACE - 1/16" ARAMID FIBER WITH SBR BINDER - GARLOCK BLUE-GARD OR EQUAL	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
STAINLESS STEEL	ASTM B36.10M	ASME B31.1		1	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-PCW (SS)	STAINLESS STEEL	150 PSIG	ASME B31.1	ASME B16.34	
GATE VALVE	PIPE SIZE (NPS)	2" AND SMALLER		2 1/2" THRU 24"	
	CONNECTION AND RATING	--		CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY: ASTM A351 CF8M BONNET: ASTM A351 CF8M DISC: ASTM A351 CF8M STEM: ASTM A276 T316 PACKING: PTFE	
VALVE SELECTION	--		POWELL FIGURE 1503 CRANE FIGURE 47 (THRU 24") BONNEY FORGE 1-18 RF		
BUTTERFLY VALVE	CONNECTION AND RATING	--		LUGGED FOR CLASS 150 FLANGED ENDS	
	CONSTRUCTION	--		BODY: A182 GR. F316 OR A351 GR. CF8M SEAT: TFE/VITON DISC: A182 GR. F316 OR A351 GR. CF8M SHAFT: 17-4 PH PACKING: TFE	
	VALVE SELECTION	--		POWELL FIGURE 1572 CRANE FLOWSEAL TYPE 1LA (12" AND SMALLER) TYPE 1LC (14" AND LARGER) JAMESBURY SERIES 815	
CHECK VALVE	CONNECTION AND RATING	CLASS 200 PSIG THREADED		--	
	CONSTRUCTION	BODY/CAP: A182 F316L CARRIER/CARRIER PIN: 316SS DISC: A276 T316 SEAT RING: 316 SST GASKET: SPIRAL WOUND SST WITH PTFE		BODY: ASTM A351 GR. CF8M CAP: ASTM A351 GR. CF8M CARRIER/CARRIER PIN: 316SS DISC: ASTM A351 GR. CF8M GASKET: PTFE	
	VALVE SELECTION	POWELL FIGURE SW08 VOGT SERIES SWS718 BONNEY FORGE HL-68-SW		POWELL FIGURE 1561 CRANE FIGURE 147 (THRU 24") BONNEY FORGE 1-68 RF	
BALL VALVE	CONNECTION AND RATING	CLASS 800 SOCKETWELD		CLASS 150 FLANGED ENDS (2-1/2" THRU 20")	
	CONSTRUCTION	BODY/BONNET: ASTM A351, CF8M STAINLESS STEEL, FULL-PORT SEAT RING: XTREME BALL: SS 316 SEAL: PTFE PACKING: GRAPHITE		BODY/INSERT: A351 CF8M BALL: 316 SS STEM: 316 SS SEAT: PTFE BODY SEAL: TFM STEM SEAL: PTFE GEAR OPERATOR 4" AND LARGER	
	VALVE SELECTION	JAMESBURY SERIES 4000 MODEL A KECKLEY SYTE BVM3 KITZ U3TZM		JAMESBURY SERIES 7150 KECKLEY BVF1 (THRU 6") VELAN SB-150	
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
0	INITIAL ISSUE			12/5/2018	
1	ADDED VALVE MANUFACTURERS			1/21/2021	

PROCESS WATER - DI (TO 150 PSIG)

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:	
UI-PCW-DI	PIPE SIZE (NPS)	PROCESS WATER - OUTSIDE	150 PSIG at 150 °F	
	WEIGHT/SCHEDULE	3" THRU 24"		
PIPE MATERIAL:	MATERIAL	SPECIAL THICKNESS CLASS 53 ANSI/AWWA C150/A21.50		
ANSI/AWWA C151/A21.51	CONSTRUCTION	ANSI/AWWA C151/A21.51 DUCTILE IRON PIPING		
FITTINGS:	DESIGN RATING	ANSI/AWWA C110/A21.10 FLANGED		
	MATERIAL	150 PSIG IN ACCORDANCE WITH ANSI/AWWA C110/A21.10 DUCTILE IRON		
JOINTS:	TYPE	ANSI/AWWA C115/A21.15 FLANGED		
	DESIGN RATING	250 PSIG IN ACCORDANCE WITH ANSI/AWWA C115/A21.15		
SERVICE SADDLES:	OTHER	-		
	CONSTRUCTION	ASTM A536 DUCTILE IRON		
	DESIGN RATING	350 PSIG IN ACCORDANCE WITH ANSI/AWWA C800		
	COATING	FUSION BONDED BLACK NYLON		
FLANGES:	STRAPS	TYPE 304 STAINLESS STEEL		
	CONSTRUCTION	CLASS 150 - WELD NECK - ASME B16.5		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
BOLTS:	MATERIAL	FORGED CARBON STEEL - ASTM A105		
	CONSTRUCTION	STAINLESS STEEL IN ACCORDANCE WITH ASTM A240		
NUTS:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H		
WASHERS:	CONSTRUCTION	TYPE 304 STAINLESS STEEL		
GASKETS:	CONSTRUCTION	SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES AND FOR USE WITH SERVICE SADDLES		
	STANDARD	ANSI/AWWA C111/A21.11		
	MATERIAL	FULL FACE - 1/16" ARAMID FIBER WITH SBR BINDER - GARLOCK BLUE-GARD OR EQUAL		
PIPE LINING:	CONSTRUCTION	CEMENT MORTAR LINING AND SEAL COAT		
	STANDARD	ANSI/AWWA C104/A21.4		
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:	DATE REVISED:
DUCTILE IRON	ANSI/AWWA C151/A21.51	--	0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:	
UI-PCW-DI	DUCTILE IRON	--	--	--
	PIPE SIZE (NPS)	3" THRU 24"		
BUTTERFLY VALVE	CONNECTION AND RATING	LUGGED FOR CLASS 150 FLANGES		
	CONSTRUCTION	BODY/SEAT: CARBON STEEL STEM: SS DISC: SS GLAND/BEARING: SS WITH RTFE IMPREGNATED OPERATOR: GEARED HANDWHEEL W/ POSITION INDICATOR SEAT: PTFE 200 PSIG WORKING PRESSURE		
	VALVE SELECTION	ABZ SERIES 400 DEZURIK STYLE BHP JAMESBURY SERIES 815		
NOTES:				
1) DESIGN PROFESSIONAL SHALL DISCUSS THE USE OF DUCTILE IRON PIPING IN PROCESS WATER SERVICE WITH UTILITY OPERATOR DURING PROJECT DESIGN				
REVISION HISTORY				
NUMBER	DESCRIPTION	DATE		
0	INITIAL ISSUE	2/22/2021		

**CHEMICAL TREATMENT SERVICE
- SAMPLE WATER (TO 150 PSIG)**

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-CSS	PIPE SIZE (NPS)	CHEMICAL TREATMENT		150 PSIG AT 100 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 6"	
PIPE MATERIAL:	ASME B36.10M	WALL THICKNESS	SCH 80, SDR 21 OR 26	CONNECTION AND RATING	SCH 80, SDR 21 OR 26
FITTINGS:	MATERIAL	POLYVINYL CHLORIDE (PVC) ASTM D1784, WITH CELL CLASS OF 12454		POLYVINYL CHLORIDE (PVC) ASTM D1784, WITH CELL CLASS OF 12454	
	CONSTRUCTION	SOLVENT WELD TYPE		SOLVENT WELD TYPE	
	STANDARD	ASTM D2467		ASTM F1970	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
JOINTS:	SOLVENT MATERIAL	SOLVENT CEMENT IN ACCORDANCE WITH ASTM D2564		SOLVENT CEMENT IN ACCORDANCE WITH ASTM D2564	
	CONSTRUCTION	SOLVENT WELD TYPE		SOLVENT WELD TYPE	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
FLANGES:	SOLVENT MATERIAL	SOLVENT CEMENT IN ACCORDANCE WITH ASTM D2564		SOLVENT CEMENT IN ACCORDANCE WITH ASTM D2564	
	CONSTRUCTION	FLANGE ONLY PERMITTED FOR EQUIPMENT OR VALVE CONNECTIONS		FLANGE ONLY PERMITTED FOR EQUIPMENT OR VALVE CONNECTIONS	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
FLANGE BOLTS:	MATERIAL	POLYVINYL CHLORIDE (PVC) ASTM F1970, WITH CLASS 150 FLANGE DIMENSIONS		POLYVINYL CHLORIDE (PVC) ASTM F1970, WITH CLASS 150 FLANGE DIMENSIONS	
	CONSTRUCTION	CARBON STEEL BOLTS AND STUDS IN ACCORDANCE WITH ASTM A307		CARBON STEEL BOLTS AND STUDS IN ACCORDANCE WITH ASTM A307	
FLANGE NUTS:	MATERIAL	HEAVY HEX - A194 GRADE 8		HEAVY HEX - A194 GRADE 8	
GASKETS:	CONSTRUCTION	SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES		SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
	MATERIAL	FULL FACE - 1/8" POLYTETRAFLUOETHYLENE (PTFE) - GARLOCK 3500 OR EQUAL		FULL FACE - 1/8" POLYTETRAFLUOETHYLENE (PTFE) - GARLOCK 3500 OR EQUAL	
PIPE MATERIAL:	PVC 1120	PIPE CODE:	ASTM B36.10M	DESIGN/CONSTRUCTION CODE:	ASME B31.1 (2012)
VALVE SPECIFICATION:	PVC	PRESSURE CLASS:	150	REVISION:	0
UI-CSS	PIPE SIZE (NPS)	ASME B31.1		DATE REVISED:	2/22/2021
	CONNECTION AND RATING	CLASS: 150 SOCKETWELD			
CHECK VALVE	CONSTRUCTION	BODY: ASTM D1784 CELL CLASS 12454, PVC, TYPE IV, "TRUE UNION" STYLE BALL: PVC, TYPE IV, ASTM D1784, CELL CLASSIFICATION 12454 SEAT PLATE: PVC, TYPE IV, ASTM D1784, CELL CLASSIFICATION 12454 PACKING: GRAPHITE O-RING: FKM			
	VALVE SELECTION	SPEARS TRUE UNION 2000 COLONIAL TRUE UNION CHECK VALVE HAYWARD TC SERIES			
BALL VALVE	CONNECTION AND RATING	CLASS: 150 SOCKETWELD			
	CONSTRUCTION	BODY: ASTM D1784 CELL CLASS 12454, PVC, SCH. 80, FULL-PORT, "TRUE UNION" STYLE BALL: PVC, TYPE 1, ASTM D1784, CELL CLASSIFICATION 12454 SEAT: PTFE STEM: PVC, TYPE 1, ASTM D1784, CELL CLASS 12454 HANDLE: POLYPROPYLENE PACKING: GRAPHITE O-RING: EPDM			
	VALVE SELECTION	SPEARS TRUE UNION 2000 COLONIAL FULL BLOCK INDUSTRIAL TRUE UNION BALL VALVE HAYWARD TB SERIES			
REVISION HISTORY					
NUMBER	DESCRIPTION			DATE	
0	INITIAL ISSUE			2/22/2021	

**CHEMICAL FEED (SS)
(TO 150 PSIG)**

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:														
UI-CHEM (SS)		CHEMICAL FEED		150 PSIG AT 140 °F														
PIPE MATERIAL:		PIPE SIZE (NPS)		2" AND SMALLER														
ASME B36.10M		WEIGHT/SCHEDULE		TUBE WALL THICKNESS VARIES BY LINE SIZE														
		MATERIAL		ASTM A269 AND A213 TYPE 316/316L SEAMLESS TUBING - HARDNESS NOT TO EXCEED 90 HRB OR 200 HV														
TUBING WALL:		TUBING OD (IN.)		1/16	1/8	3/16	1/4	5/16	3/8	1/2	5/8	3/4	7/8	1	1 1/4	1 1/2	2	
		WALL THICKNESS (IN.)		0.010	0.028	0.028	0.028	0.035	0.035	0.035	0.049	0.049	0.049	0.049	0.065	0.083	0.095	0.109
FITTINGS:		CONSTRUCTION		SWAGelok COMPRESSION TUBING FITTINGS														
		WALL THICKNESS		SAME AS ADJOINING PIPE														
		MATERIAL		ASTM A276, TYPE 316 AND ASTM A182 TYPE 316														
PIPING JOINTS:		TYPE		SWAGelok COMPRESSION TUBING FITTINGS														
		OTHER		--														
FLANGES:		CONSTRUCTION		FLANGES NOT PERMITTED														
		WALL THICKNESS		--														
		MATERIAL		--														
FLANGE BOLTS:		CONSTRUCTION		FLANGES NOT PERMITTED														
		MATERIAL		--														
FLANGE NUTS:		CONSTRUCTION		FLANGES NOT PERMITTED														
		MATERIAL		--														
GASKETS:		CONSTRUCTION		FLANGES NOT PERMITTED														
		MATERIAL		--														
PIPE MATERIAL:		PIPE CODE:		DESIGN/CONSTRUCTION CODE:								REVISION:		DATE REVISED:				
STAINLESS STEEL		ASTM B36.10M		ASME B31.1								2		2/22/2021				
VALVE SPECIFICATION:		SPECIFICATION MATERIAL:		PRESSURE CLASS:		DESIGN CODE:												
		CARBON STEEL		150 PSIG		ASME B31.1												
UI-CHEM (SS)		PIPE SIZE (NPS)		2" AND SMALLER														
BALL VALVE		CONNECTION AND RATING		SWAGelok COMPRESSION TUBING FITTINGS														
		CONSTRUCTION		BODY: ASTM A479 316SS BALL: ASTM A276 OR A479 316SS STEM: STM A276 OR A479 316SS SEATS, STEM BEARING AND PACKING: PEEK														
		VALVE SELECTION		SWAGelok SS-62P														

REVISION HISTORY		
NUMBER	DESCRIPTION	DATE
1	ADDED WALL THICKNESS TO TABLE, REMOVED OTHER REFERENCES TO WALL THICKNESS	9/22/2017
2	CHANGED CONSTRUCTION TO 2" AND SMALLER TUBING SPEC	2/22/2021

**CHEMICAL FEED (PVC)
(TO 150 PSIG)**

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:	
UI-CHEM (PVC)	PIPE SIZE (NPS)	CHEMICAL FEED	150 PSIG AT 140 °F	
	WEIGHT/SCHEDULE		2" AND SMALLER	
PIPE MATERIAL: ASME B36.10M	MATERIAL	POLYVINYL CHLORIDE (PVC) ASTM D1784, WITH CELL CLASS OF 12454		
FITTINGS:	CONSTRUCTION	SOLVENT WELD TYPE		
	STANDARD	ASTM D2467		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
JOINTS:	SOLVENT MATERIAL	SOLVENT CEMENT IN ACCORDANCE WITH ASTM D2564		
	CONSTRUCTION	SOLVENT WELD TYPE		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
FLANGES:	SOLVENT MATERIAL	SOLVENT CEMENT IN ACCORDANCE WITH ASTM D2564		
	CONSTRUCTION	FLANGE ONLY PERMITTED FOR EQUIPMENT OR VALVE CONNECTIONS		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
FLANGE BOLTS:	MATERIAL	POLYVINYL CHLORIDE (PVC) ASTM F1970, WITH CLASS 150 FLANGE DIMENSIONS		
FLANGE NUTS:	CONSTRUCTION	CARBON STEEL BOLTS AND STUDS IN ACCORDANCE WITH ASTM A307		
GASKETS:	MATERIAL	HEAVY HEX - A194 GRADE 8		
	CONSTRUCTION	SUITABLE FOR FLAT-FACE FLANGES		
PIPE MATERIAL: PVC 1120	PIPE CODE: ASTM B36.10M	DESIGN/CONSTRUCTION CODE: ASME B31.1	REVISION: 0	DATE REVISED: 2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL: PVC	PRESSURE CLASS: 150	DESIGN CODE: ASME B31.1	ASME B16.34
UI-CHEM (PVC)	PIPE SIZE (NPS)	2" AND SMALLER		
	CONNECTION AND RATING	CLASS 150 SOCKETWELD		
CHECK VALVE	CONSTRUCTION	BODY: ASTM D1784 CELL CLASS 12454, PVC, TYPE IV, "TRUE UNION" STYLE BALL: PVC, TYPE IV, ASTM D1784, CELL CLASSIFICATION 12454 SEAT PLATE: PVC, TYPE IV, ASTM D1784, CELL CLASSIFICATION 12454 PACKING: GRAPHITE O-RING: FKM		
	VALVE SELECTION	SPEARS TRUE UNION 2000 COLONIAL TRUE UNION CHECK VALVE HAYWARD TC SERIES		
BALL VALVE	CONNECTION AND RATING	CLASS 150 SOCKETWELD		
	CONSTRUCTION	BODY: ASTM D1784 CELL CLASS 12454, PVC, SCH. 80, FULL-PORT, "TRUE UNION" STYLE BALL: PVC, TYPE 1, ASTM D1784, CELL CLASSIFICATION 12454 SEAT: PTFE STEM: PVC, TYPE 1, ASTM D1784, CELL CLASS 12454 HANDLE: POLYPROPYLENE PACKING: GRAPHITE O-RING: EPDM		
	VALVE SELECTION	SPEARS TRUE UNION 2000 COLONIAL FULL BLOCK INDUSTRIAL TRUE UNION BALL VALVE HAYWARD TB SERIES		

REVISION HISTORY		
NUMBER	DESCRIPTION	DATE
0	INITIAL ISSUE	2/22/2021

**CHEMICAL TREATMENT SERVICE
(TO 150 PSIG)**

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-CHEM (CPVC)	PIPE SIZE (NPS)	CHEMICAL TREATMENT		150 PSIG AT 100°F	
	WEIGHT/SCHEDULE	2" AND SMALLER		2 1/2" THRU 6"	
PIPE MATERIAL:	PIPE MATERIAL:	SCH 80		SCH 80	
	ASTM F441	MATERIAL	CHLORINATED POLYVINYL CHLORIDE (CPVC) ASTM D1784 TYPE IV, GRADE 1, WITH CELL CLASS OF 23447	CHLORINATED POLYVINYL CHLORIDE (PVC) ASTM D1784 TYPE IV, GRADE 1, WITH CELL CLASS OF 23447	
FITTINGS:	CONSTRUCTION	SOLVENT/SOCKET WELD TYPE		FABRICATED	
	STANDARD	ASTM F439		ASTM F1970	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
JOINTS:	SOLVENT MATERIAL	SOLVENT CEMENT IN ACCORDANCE WITH ASTM F493		SOLVENT CEMENT IN ACCORDANCE WITH ASTM F493	
	CONSTRUCTION	SOLVENT WELD TYPE		SOLVENT WELD TYPE	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
FLANGES:	SOLVENT MATERIAL	SOLVENT CEMENT IN ACCORDANCE WITH ASTM F493		SOLVENT CEMENT IN ACCORDANCE WITH ASTM F493	
	CONSTRUCTION	FLANGE ONLY PERMITTED FOR EQUIPMENT OR VALVE CONNECTIONS		FLANGE ONLY PERMITTED FOR EQUIPMENT OR VALVE CONNECTIONS	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
FLANGE BOLTS:	MATERIAL	CHLORINATED POLYVINYL CHLORIDE (CPVC) ASTM F1970, WITH CLASS 150 FLANGE DIMENSIONS		CHLORINATED POLYVINYL CHLORIDE (CPVC) ASTM F1970, WITH CLASS 150 FLANGE DIMENSIONS	
	CONSTRUCTION	CARBON STEEL BOLTS AND STUDS IN ACCORDANCE WITH ASTM A307		CARBON STEEL BOLTS AND STUDS IN ACCORDANCE WITH ASTM A307	
FLANGE NUTS:	MATERIAL	HEAVY HEX - A194 GRADE 8		HEAVY HEX - A194 GRADE 8	
GASKETS:	CONSTRUCTION	SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES		SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
	MATERIAL	FULL FACE - 1/8" POLYTETRAFLUOETHYLENE (PTFE) - GARLOCK 3500 OR EQUAL		FULL FACE - 1/8" POLYTETRAFLUOETHYLENE (PTFE) - GARLOCK 3500 OR EQUAL	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
CPVC (ASTM D1784)	ASTM F441	ASME B31.1		0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-CHEM (CPVC)	CHLORINATED POLYVINYL CHLORIDE (CPVC)	235 PSIG at 73°F	ASME B31.1	ASTM F1970	
CHECK VALVE	PIPE SIZE (NPS)	1/2" THRU 6"			
	CONNECTION AND RATING	CLASS: 150 SOCKETWELD			
	CONSTRUCTION	BODY: ASTM D1784 CELL CLASS 23447, CPVC, TYPE IV, "TRUE UNION" STYLE BALL: CPVC, TYPE IV, ASTM D1784, CELL CLASSIFICATION 23447 SEAT PLATE: CPVC, TYPE IV, ASTM D1784, CELL CLASSIFICATION 23447 O-RINGS: FKM			
VALVE SELECTION	SPEARS TRUE UNION 2000 COLONIAL TRUE UNION CHECK VALVE HAYWARD TC SERIES				
BALL VALVE	CONNECTION AND RATING	CLASS: 150 SOCKETWELD			
	CONSTRUCTION	BODY: ASTM D1784 CELL CLASS 23447, CPVC, SCH. 80, FULL-PORT, "TRUE UNION" STYLE BALL: CPVC, TYPE 1, ASTM D1784, CELL CLASSIFICATION 23447 SEAT: PTFE STEM: CPVC, TYPE 1, ASTM D1784, CELL CLASS 23447 HANDLE: POLYPROPYLENE PACKING: GRAPHITE O-RINGS: FKM			
	VALVE SELECTION	SPEARS TRUE UNION 2000 COLONIAL FULL BLOCK INDUSTRIAL TRUE UNION BALL VALVE HAYWARD TB SERIES			

NOTES:

- 1) FOR USE WITH LIQUID SERVICE. NOT FOR COMPRESSED AIR OR GAS SERVICE.
- 2) PRESSURE RATINGS FOR FITTINGS AND FLANGES SHALL MEET OR EXCEED MAXIMUM WORKING PRESSURE.

REVISION HISTORY		
NUMBER	DESCRIPTION	DATE
0	INITIAL ISSUE	2/22/2021

**CHEMICAL TREATMENT
SERVICE - ACID (TO 150 PSIG)**

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-CHEM (PVDF)	PIPE SIZE (NPS)	CHEMICAL TREATMENT 2" AND SMALLER		150 PSIG AT 100 °F 2 1/2" THRU 6"	
	WEIGHT/SCHEDULE	SCH 80		SCH 80	
PIPE MATERIAL:	MATERIAL	POLYVINYLIDENE FLUORIDE (PVDF) ASTM D3222 FOR TYPE I HOMOPOLYMERS WITH 1.7% RED PIGMENT		POLYVINYLIDENE FLUORIDE (PVDF) ASTM D3222 FOR TYPE I HOMOPOLYMERS WITH 1.7% RED PIGMENT	
FITTINGS:	CONSTRUCTION	HEAT FUSION WELDED		HEAT FUSION WELDED	
	STANDARD	ASTM D2467		ASTM D2467	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
JOINTS:	CONSTRUCTION	HEAT FUSION WELDED		HEAT FUSION WELDED	
	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	CONSTRUCTION	FLANGES NOT PERMITTED		FLANGES NOT PERMITTED	
FLANGES:	WALL THICKNESS	--		--	
	MATERIAL	--		--	
FLANGE BOLTS:	CONSTRUCTION	--		--	
FLANGE NUTS:	MATERIAL	--		--	
GASKETS:	CONSTRUCTION	--		--	
	MATERIAL	--		--	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISION:
PVDF (ASTM D3222)	ASTM D1785	ASME B31.1		0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-CHEM (PVDF)	POLYVINYLIDENE FLUORIDE (PVDF)	150 PSIG at 73°F	ASME B31.1	--	
	PIPE SIZE (NPS)	1/2" THRU 4"			
CHECK VALVE	CONNECTION AND RATING	CLASS: 150 SOCKETWELD			
	CONSTRUCTION	BODY: ASTM D3222, WITH CELL CLASS TYPE II, RED PVDF, SCH. 80, FULL-PORT, "TRUE UNION" STYLE BALL: PVDF, ASTM D3222, WITH CELL CLASS TYPE II SEAT: FKM STOP RING: RED PVDF O-RING: FKM			
	VALVE SELECTION	NIBCO PVDF TRU UNION BALL CHECK WATTS PVDF TRUE UNION BALL CHECK			
BALL VALVE	CONNECTION AND RATING	CLASS: 150 SOCKETWELD			
	CONSTRUCTION	BODY: ASTM D3222, WITH CELL CLASS TYPE II, RED PVDF, SCH. 80, FULL-PORT, "TRUE UNION" STYLE BALL: PVDF, ASTM D3222, WITH CELL CLASS TYPE II SEAT: PTFE STEM: PVDF, ASTM D3222, WITH CELL CLASS TYPE II HANDLE: POLYPROPYLENE PACKING: GRAPHITE O-RINGS: FKM			
	VALVE SELECTION	NIBCO PVDF TRU-BLOC MODEL C WATTS PVDF TRUE UNION BALL			

NOTES:

- 1) FOR USE WITH LIQUID SERVICE. NOT FOR COMPRESSED AIR OR GAS SERVICE.
- 2) PRESSURE RATINGS FOR FITTINGS AND FLANGES SHALL MEET OR EXCEED MAXIMUM WORKING PRESSURE.

REVISION HISTORY		
NUMBER	DESCRIPTION	DATE
0	INITIAL ISSUE	11/19/2020

**DOMESTIC WATER SYSTEMS
(TO 135 PSIG)**

PIPING SPECIFICATION:		PROCESS:		DESIGN CONDITIONS:	
UI-DCW	PIPE SIZE (NPS)	DOMESTIC COLD AND HOT WATER 4" AND SMALLER (NOTE 1)		135 PSIG AT 200 °F 2 1/2" THRU 24" (NOTE 1)	
	WEIGHT/SCHEDULE	--		STD	
PIPE MATERIAL: ASME B36.10M/B88	MATERIAL	ASTM B88 COPPER, TYPE K, HARD DRAWN		ASTM A53 GRADE B - SEAMLESS GALVANIZED	
	CONSTRUCTION	SOLDERED OR PRESS FIT		BUTT WELD	
FITTINGS:	WALL THICKNESS	SAME AS ADJOINING PIPE		SAME AS ADJOINING PIPE	
	MATERIAL	ASME B16.18 CAST COPPER OR ASME B16.22 WROUGHT COPPER ALLOY		CLASS 125 FLANGED	
	TYPE	SOLDERED OR PRESS FIT		CLASS 125 FLANGED	
PIPING JOINTS:	OTHER	SEE BELOW FOR JOINT DETAILS		--	
	CONSTRUCTION	SOLDER: ASTM B32 ALLOY, GRADE Sb-5 95/5 TIN-ANTIMONY, LEAD FREE OR: ASTM B32 ALLOY, GRADE SN95 TIN-SILVER, LEAD FREE		CLASS 150 - WELD NECK - ASME B16.5	
SOLDER/FLANGES:	WALL THICKNESS	--		SAME AS ADJOINING PIPE	
	MATERIAL	--		GALVANIZED STEEL - ASTM A105	
	CONSTRUCTION	SOLDER: FILLER METAL LEAD-FREE - WATER-FLUSHABLE FLUX ASTM B813 - SILVER BRAZING FILLER METAL SHALL BE BCuP SERIES, COPPER PHOSPHORUS ALLOYS FOR GENERAL DUTY BRAZING - AWS A5.8		STUD - FULL LENGTH ASME B1.1	
SOLDER/FLANGE BOLTS:	MATERIAL	--		ASTM A307 - GRADE B, FULL LENGTH STUD	
	CONSTRUCTION	--		HEAVY HEX - ASME B1.1 - CLASS 2B THREADS	
PRESS FIT/FLANGE NUTS:	MATERIAL	PRESS FIT: MATERIALS CONFORM TO ASME B16.18 OR: ASME B16.22 AND CRITERIA UNDER IAPMO PS 117 - SEALING ELEMENTS: EPDM - SEALING ELEMENTS FACTORY INSTALLED - FITTINGS SHALL BE PRESSED BY TOOLS RECOMMENDED BY FITTING MANUFACTURER		CARBON STEEL - ASTM A194 GRADE 2H HEAVY - F436 WASHERS	
	CONSTRUCTION	--		SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES	
PRESS FIT/GASKETS:	MATERIAL	--		FULL FACE - RED RUBBER	
	PIPE CODE:	DESIGN/CONSTRUCTION CODE:		REVISION:	DATE REVISED:
COPPER/CARBON STEEL	ASTM B36.10M	ASME B31.1		0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:		
UI-DCW	AS NOTED	125 PSIG	ASME B31.1	ASME B16.34	
	PIPE SIZE (NPS)	4" AND SMALLER (NOTE 1)		2 1/2" THRU 24" (NOTE 1)	
GATE VALVE	CONNECTION AND RATING	--		CLASS 125 FLANGED ENDS	
	CONSTRUCTION	--		IN ACCORDANCE WITH MSS SP-70 BODY/SEAT: ASTM A395 CAST IRON SHAFT: B16 BRASS DISC: BRONZE INTERNALS: BRONZE SEATS AND SEALS: RENEWABLE BRONZE OS&Y CLASS 125	
	VALVE SELECTION	--		POWELL FIG. NO. 1793 CRANE F84 ELITE GTVA-FC1333-HW	
BALL VALVE	CONNECTION AND RATING	CLASS 200 PSIG SOLDERED OR PRESS FIT		--	
	CONSTRUCTION	BODY: C89836 LEAD-FREE BRONZE, STANDARD PORT BALL: C27451 LEAD-FREE BRASS STEM: C27451 LEAD-FREE BRASS SEATS/SEALS: RPTFE PACKING: RPTFE LOCKABLE, QUARTER TURN LEVER HANDLE		--	
	VALVE SELECTION	APOLLO 70LF SERIES (SOLDER) APOLLO 77VLF SERIES (PRESS FIT) NIBCO 580 LF SERIES (THRU 3") MILWAUKEE UPBA-480B (PRESS FIT ENDS)		--	

NOTES:

1) PIPE SIZE RANGE OVERLAP IS INTENTIONAL. EITHER MATERIAL CAN BE USED BETWEEN 2-1/2" AND 4" PENDING DESIGN PROFESSIONAL DISCUSSION WITH UTILITY OPERATOR.

REVISION HISTORY

NUMBER	DESCRIPTION	DATE
0	INITIAL ISSUE	12/1/2017
1	ADDED MODEL NUMBER FOR NIBCO BALL VALVE, ADDED VALVE MANUFACTURERS	2/22/2021

LUBE OIL (TO 230 PSIG)

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:	
UI-LOL	PIPE SIZE (NPS)	LUBE OIL	230 PSIG AT 100 °F	
	WEIGHT/SCHEDULE	2" AND SMALLER	2 1/2" THRU 10"	12" THRU 24"
PIPE: ASME B36.10M	MATERIAL	SCH 40S	SCH 10S	SCH 40S
	CONSTRUCTION	ASTM A312 TYPE 304 - SEAMLESS	ASTM A312 TYPE 304 - SEAMLESS	
FITTINGS:	WALL THICKNESS	CLASS 3000 - SOCKETWELD - B16.11	BUTTWELD - ASME B16.9	
	MATERIAL	SAME AS ADJOINING PIPE	SAME AS ADJOINING PIPE	
PIPING JOINTS:	TYPE	FORGED STEEL - ASTM A182, F304L, ASME 16.11	ASTMA403, WP304L - SEAMLESS, ASME B16.25	
	OTHER	SOCKETWELD	BUTTWELD - END PREP PER B16.25	
FLANGES:	CONSTRUCTION	FLANGES NOT PERMITTED	FLANGES NOT PERMITTED	
	WALL THICKNESS	--	--	
FLANGE BOLTS:	MATERIAL	--	--	
	CONSTRUCTION	--	--	
FLANGE NUTS:	CONSTRUCTION	--	--	
WASHER:	CONSTRUCTION	--	--	
GASKETS:	CONSTRUCTION	--	--	
	MATERIAL	--	--	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:	DATE REVISED:
STAINLESS STEEL	ASTM B36.10M	ASME B31.1	0	2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:	
UI-LOL	STAINLESS STEEL	300 PSIG	ASME B31.1	MSS SP-110
	PIPE SIZE (NPS)	2" AND SMALLER	2 1/2" THRU 10"	
BALL VALVE	CONNECTION AND RATING	CLASS 300 THREADED		
	CONSTRUCTION	BODY/BONNET: ASTM A351, CF8M STAINLESS STEEL, FULL-PORT SEAT RING: XTREME BALL: SS 316 STEM: SS 316 SEAL: REINFORCED PTFE PACKING: GRAPHITE		
	VALVE SELECTION	APOLLO 76F-100-A NIBCO T-585-S6-R-66-LL MILWAUKEE SERIES BA260		
REVISION HISTORY				
NUMBER	DESCRIPTION		DATE	
0	INITIAL ISSUE		2/22/2021	

REFRIGERANT (TO 300 PSIG)

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:
UI-REF	PIPE SIZE (NPS)	R134A	300 PSIG AT 250 °F
	WEIGHT/SCHEDULE	10" AND SMALLER	
PIPE MATERIAL:	WEIGHT/SCHEDULE	--	
ASME B31.5	MATERIAL	ASTM B88 COPPER, TYPE K, HARD DRAWN, SEAMLESS	
	CONSTRUCTION	BRAZED-JOINT PRESSURE TYPE	
FITTINGS:	WALL THICKNESS	SAME AS ADJOINING PIPE	
	MATERIAL	ASME B16.50 WROUGHT COPPER ALLOY	
PIPING JOINTS:	TYPE	BRAZED WITH BAG SERIES FILLER METAL AND CAPILLARY FITTINGS, IN ACCORDANCE WITH AWS A5.8	
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:
COPPER	ASTM B31.5	ASME B31.5	0
			2/22/2021
VALVE SPECIFICATION:	SPECIFICATION MATERIAL:	PRESSURE CLASS:	DESIGN CODE:
	AS NOTED	150 PSIG	ASME B16.34
UI-REF	PIPE SIZE (NPS)	3/8" THRU 2 5/8"	3" THRU 10"
	CONNECTION AND RATING	CLASS 500 PSIG SOLDERED OR THREADED	
	CONSTRUCTION	BODY/CAP: BRONZE STEM: SILICON BRASS SEAT: NITRILE RUBBER DISC: BRONZE, IN-LINE GASKET: SPIRAL WOUND SS WITH GRAPHITE GRAPHITE ARAMID FIBERS	
CHECK VALVE	VALVE SELECTION	HENRY VALVE COMPANY SERIES 205 ALCO SERIES EC PARKER SERIES C	
	CONNECTION AND RATING	CLASS 600 PSIG SOLDERED OR THREADED	
	CONSTRUCTION	BODY: BOLTED FORGED BRASS, 2-PIECE, FULL-PORT BALL: ELECTRO-PLATED BRASS STEM: STAINLESS STEEL WITH NOPHRENE RING STEM SEALS PACKING: PTFE SEATS AND SEALS: PTFE	
BALL VALVE	VALVE SELECTION	HENRY VALVE COMPANY SERIES 937 ALCO BVE PARKER SERIES 500	
	CONNECTION AND RATING	CLASS 500 PSIG SOLDERED OR THREADED	
	CONSTRUCTION	TYPE: ANGLE TYPE, DESIGNED, APPROVED, AND STAMPED IN ACCORDANCE WITH ANSI B9.1/ASHRAE STANDARD 15, SEALED AND STAMPED WITH ASME UV AND NATIONAL BOARD CERTIFICATION NB BODY/DISC: BRASS SEAT: NEOPRENE SETTING: 300 PSIG	
RELIEF VALVE	VALVE SELECTION	MUELLER ANGLE NPTFE TO FLARE	
REVISION HISTORY			
NUMBER	DESCRIPTION	DATE	
0	INITIAL ISSUE	2/22/2021	

REFRIGERANT VENT PIPING - CS

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:	
UI-RV		R134A OR R123	285 PSIG AT 150 °F	
	PIPE SIZE (NPS)	4" THRU 12"		
PIPE MATERIAL: ASME B31.10M	WEIGHT/SCHEDULE	SCH. 40		
	MATERIAL	ASTM A53 GRADE B - SEAMLESS		
FITTINGS:	CONSTRUCTION	BUTTWELD - B16.25		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
	MATERIAL	BUTTWELD FITTING - ASTM A234 GRADE B - SEAMLESS		
PIPING JOINTS:	TYPE	BUTTWELD - B16.25		
	OTHER	WHERE FLANGE OR THREAD REQUIRED		
UNIONS:	CONSTRUCTION	NOT PERMITTED		
	WALL THICKNESS	--		
	MATERIAL	--		
FLANGES:	CONSTRUCTION	CLASS 300 - WELD NECK - ASME B16.5 AND ASME B16.47		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
	MATERIAL	FORGED CARBON STEEL - ASTM A105 OR ASTM A516 GRADE 70		
FLANGE BOLTS:	CONSTRUCTION	HIGH-STRENGTH STEEL ASTM A193, CLASS 2, GRADE B8		
FLANGE NUTS:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H		
WASHER:	CONSTRUCTION	F436		
GASKETS:	CONSTRUCTION	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES		
	MATERIAL	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER		
	MANUFACTURER	GARLOCK BLUE-GARD 3000 OR EQUAL		
THERMOWELLS:	MATERIAL	INSERTION THERMOWELLS - ASTM A105 - 3000 PSIG PRESSURE CLASS - SEAL-WELDED WELLS		
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1	0	2/22/2021
FINISH:	SPECIFICATION MATERIAL:	2-COAT SYSTEM WITH SOLVENT-BASED INORGANIC ZINC PRIMER, AND INORGANIC SILICATE POLYMER TOP COAT - REFER TO PROJECT SPECIFICATIONS COLOR TO MATCH RED OF EXISTING RELIEF DEVICE PIPING		
REVISION HISTORY				
NUMBER	DESCRIPTION		DATE	
0	INITIAL ISSUE		2/22/2021	

REFRIGERANT VENT PIPING - SS

PIPING SPECIFICATION:		PROCESS:	DESIGN CONDITIONS:	
UI-RV		R134A OR R123	285 PSIG AT 150 °F	
	PIPE SIZE (NPS)	4" THRU 12"		
PIPE MATERIAL: ASME B31.10M	WEIGHT/SCHEDULE	SCH 10S		
	MATERIAL	A312 GRADE 304 - SEAMLESS OR WELDED		
FITTINGS:	CONSTRUCTION	BUTTWELD - ASME B16.9		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
	MATERIAL	ASTM A403, WP304L - SEAMLESS, B16.25		
PIPING JOINTS:	TYPE	BUTTWELD - END PREP PER B16.25		
	OTHER	--		
UNIONS:	CONSTRUCTION	NOT PERMITTED		
	WALL THICKNESS	--		
	MATERIAL	--		
FLANGES:	CONSTRUCTION	CLASS 300 - WELD NECK - ASME B16.5 AND ASME B16.47		
	WALL THICKNESS	SAME AS ADJOINING PIPE		
	MATERIAL	SS, ASTM A182, F330L, ASME B16.5		
FLANGE BOLTS:	CONSTRUCTION	HIGH-STRENGTH STEEL ASTM A193, CLASS 2, GRADE B8		
FLANGE NUTS:	CONSTRUCTION	HEAVY HEX - A194 GRADE 2H		
WASHER:	CONSTRUCTION	F436		
GASKETS:	CONSTRUCTION	SPIRAL WOUND - SUITABLE FOR RAISED-FACE OR FLAT-FACE FLANGES		
	MATERIAL	FLEXITALLIC STYLE CGI - TYPE 304 STAINLESS - FLEXICARB FILLER		
	MANUFACTURER	GARLOCK BLUE-GARD 3000 OR EQUAL		
THERMOWELLS:	MATERIAL	INSERTION THERMOWELLS - ASTM A105 - 3000 PSIG PRESSURE CLASS - SEAL-WELDED WELLS		
PIPE MATERIAL:	PIPE CODE:	DESIGN/CONSTRUCTION CODE:	REVISION:	DATE REVISED:
CARBON STEEL	ASTM B36.10M	ASME B31.1	0	2/22/2021
REVISION HISTORY				
NUMBER	DESCRIPTION		DATE	
0	INITIAL ISSUE		2/22/2021	

