

DEVIATION REQUEST FORM

This form shall be used by Design Professional to request a deviation from the Design Standards & Procedures and must be completed prior to bid document phase. Please complete and return via email to the UI Project Manager in .pdf format.

Date: MAY 2, 2019 Project Phase: _____
(SD, DD, CD)

UI Project Name: _____

UI Project Number: _____ Design & Construction Project Manager: _____

Design Professional: _____

Design Professional Representative: _____
(first and last name)

Email Address: _____ Phone: (____) _____

Design Standards Edition: UIHC 14R Section Number: 22 11 16 Section 5.a. Page Number: 51

Description of Deviation: (attach additional page(s) as needed)

5.a Water hammer arrestors shall not be used on any interior water systems

5.c Delete section

Justification for Deviation Request: (attach additional page(s) as needed)


The elimination of water hammer arrestors will reduce infectious risks and pathogen growth.

Attachment List: Total number of pages attached: _____

Approvals:

Capital Management


Recommended
 Recommended as Noted
 Not Recommended
 N/A


 (Signature)
 MIKE (Printed Name)

Date: 5-3-2019

UIHC Engineering Service

Recommended
 Recommended as Noted
 Not Recommended
 N/A


 (Signature)
 (Printed Name)

Date: 5-3-19

 [Department Name]
 Recommended
 Recommended as Noted
 Not Recommended
 N/A

 (Signature)
 (Printed Name)

Date: _____

 [Department Name]
 Recommended
 Recommended as Noted
 Not Recommended
 N/A

 (Signature)
 (Printed Name)

Date: _____

Design & Construction approval: 
 Director/Associate Director Date: 5/3/19