



Facilities
Management
Design & Construction

**THE UNIVERSITY OF IOWA
DESIGN STANDARDS & PROCEDURES**

07-30-2021 EDITION

**PREFERMENT #05
UIHC Ductwork Lining**

EFFECTIVE DATE: January 18, 2022

The information contained in this Preferment modifies, supplements, or replaces information contained in The University of Iowa Design Standards & Procedures.

APPLICABLE SECTION: **Section III – General Design Standards and Outline Specifications and Details**

ATTACHMENT(S): **None**



APPLICABLE TO SECTION III – General Design Standards and Outline Specifications and Details:

ITEM #1 23) Heating, Ventilating, and Air Conditioning (HVAC)

4.15. Ductwork Insulation:

Revise article 4.15.3.1 to read: Do not install exposed duct lining on any ductwork within UIHC unless authorized by the Owner. If approved, all lined ductwork must have double wall construction for infection control precautions.

END OF PREFERMENT